
From: public.access@hinckley-bosworth.gov.uk
Sent: 01 June 2023 12:33
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 23/00297/FUL
Categories: Tidd

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 01/06/2023 12:33 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	23/00297/FUL
Address:	151 Wykin Road Hinckley Leicestershire LE10 0HX
Proposal:	Change of use to C3 (residential) and erection of a two storey building containing two flats
Case Officer:	Sullivan Archer

[Click for further information](#)

Comments Details

Notes to applicant:

Comments: Surface water should be managed by sustainable methods, preferably those which disperse runoff by infiltration into the ground strata: i.e. soakaways, pervious paving, filter drains, swales, etc. and the minimisation of paved area, subject to satisfactory porosity test results and the site being free from a contaminated ground legacy. If the ground strata are insufficiently permeable to avoid discharging some surface water off-site, flow attenuation methods should be employed, either alone or in combination with infiltration systems and/or rainwater harvesting systems.

Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet (See Environment Agency guidance on the permeable surfacing of front gardens).

Kind regards

