
From: public.access@hinckley-bosworth.gov.uk
Sent: 24 March 2023 10:42
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 23/00247/FUL

Categories: Rudi

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 24/03/2023 10:42 AM from Mr Simon Smith (simon.smith@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 1.

Application Summary

Reference:	23/00247/FUL
Address:	Unit 2 22 Fieldfare Road Hinckley Leicestershire LE10 3FY
Proposal:	New shopfront, two air conditioning condenser units, and two extract grilles.
Case Officer:	Joseph Fleetwood

[Click for further information](#)

Comments Details

It needs to be detailed what the extract grills serve and how potential odour impact on residential is mitigated.

Comments: It is not clear if the air conditioning units are enclosed or surrounded by boundary fencing. This information should be submitted to gauge potential impact from noise on residential. This information should also include the distance in meters between the units and the nearest residential.

Kind regards