Lisa Clarke

From: planning@hinckley-bosworth.gov.uk
Posted At: 12 March 2009 10:43
Conversation: ConsulteeAccess for Planning - Application Comments (09/00155/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00155/FUL)

ConsulteeAccess for Planning - Application Comments (09/00155/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 12/03/2009 10:42:34 from IP 192.168.0.3.

Application Summary

Application Number:
09/00155/FUL

Address:
The Copper Kettle Cafe
Watling Street
Witherley
Atherstone
Leicestershire
CV9 1RE

Proposal:
REPLACEMENT OF THE EXISTING CATERING CARAVAN WITH A PORTABLE BUILDING AND RETENTION OF THE USE OF THE LAND

Case Officer:
James Hicks

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
If the soakaway is a proposed new construction, the suitability of the ground strata for soakaway drainage should be ascertained by means of the test described in BRE Digest 365, and the results approved by the Building Control Surveyor before development is commenced. The soakaway must be constructed either as a brick or

concrete-lined perforated chamber with access for maintenance or, alternatively, assembled from units of one of the newer, modular systems, comprising cellular tanks and incorporating silt traps. Design and construction of all types of soakaway will be subject to the approval of the Building Control Surveyor.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.