

Application address Land at Crabtree Farm, Hinckley Road, Barwell		Planning ref.	23/01175/FUL 23/01177/FUL 23/01184/FUL 23/01186/FUL
		Our ref.	2023/1175/04/F/R4
Description Residential development of 51, 45, 16 and 14 dwellings (respective to planning reference in numerical order) (126 in total) with associated access, parking, LEAP and open space (revised scheme of 21/00695/FUL)		Consultation date	21/10/2024
		Response date	11/11/2024
Planning officer	Tim Hartley	Reviewing officer	Jess Nobbs
Application type	Full	Extension requested	☒
Refer to standing advice ☐	Conditions ☒	Further consultation required ☐	Concerns ☐

Consultation checklist

No.	Description	Check
1	Location plan	☒
2	Proposed layout plan	☒
3	Evidence that the site can be drained	☒
4	Topographic and ground investigation details	☒
5	The total impermeable area pre and post development	☒
6	All potential flood risk sources have been identified and assessed	☒
7	Existing and proposed peak discharge rates	☒
8	Consideration of sustainable drainage systems	☒
9	Attenuation volume calculations	☒
10	Consideration of the maintenance and management of all drainage elements	☒

LLFA Key Observations and Advice

This response represents a combined response to 4 separate full applications which are ultimately 4 phases of the same development with reliance between them. This approach has been discussed and agreed by the Local planning Authority (LPA). The proposals are for a 4.6ha development site at Crabtree Farm for 126 dwellings. This site was originally submitted as 21/00695/FUL for 51 dwellings; these new submissions include a larger area to the west.

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that the greenfield site is located within Flood Zone 1 being at low risk of fluvial flooding and a low to medium risk of surface water flooding. A vein of medium to high surface water flood risk transects the site. This could indicate an on-site ordinary watercourse or surface water flow path that transects the site. It should be noted that there are some ongoing surface water issues around the development site/in the Hinckley Road area.

The surface water drainage proposals are shown together with other phases of the development covered in other planning applications. The majority of the proposals seek to discharge at 14.8 l/s via attenuation tanks and a wet attenuation pond to the on-site watercourse at the site's northern boundary and 3.5 l/s via a below ground attenuation tank for the north-east portion of the site only.

Following a meeting between the applicant and the LLFA on 25/09 the points raised in the previous response dated 15/08 have been discussed. Following that, the LLFA are happy that sufficient information, specifically relating to the condition of the pipework and connectivity to the wider network has been provided to satisfy our concerns.

Leicestershire County Council as Lead Local Flood Authority (LLFA) advises the Local Planning Authority (LPA) that the proposals are considered acceptable to the LLFA and we advise the following planning conditions be attached to any permission granted.

Advised Conditions

1. No development approved by this planning permission shall take place until such time as a surface water drainage scheme has been submitted to, and approved in writing by the Local Planning Authority. The development must be carried out in accordance with these approved details and completed prior to first occupation.

Reason: To prevent flooding by ensuring the satisfactory storage and disposal of surface water from the site.

2. No development approved by this planning permission shall take place until such time as details in relation to the management of surface water on site during construction of the development has been submitted to, and approved in writing by the Local Planning Authority. The construction of the development must be carried out in accordance with these approved details.

Reason: To prevent an increase in flood risk, maintain the existing surface water runoff quality, and to prevent damage to the final surface water management systems through the entire development construction phase.

3. No occupation of the development approved by this planning permission shall take place until such time as details in relation to the long-term maintenance of the surface water drainage system within the development have been submitted to and approved in writing by the Local Planning Authority. The surface water drainage system shall then be maintained in accordance with these approved details in perpetuity.

Reason: To establish a suitable maintenance regime that may be monitored over time; that will ensure the long-term performance, both in terms of flood risk and water quality, of the

surface water drainage system (including sustainable drainage systems) within the proposed development.

4. No development approved by this planning permission shall take place until such time as infiltration testing has been carried out (or suitable evidence to preclude testing) to confirm or otherwise, the suitability of the site for the use of infiltration as a drainage element, has been submitted to and approved in writing by the Local Planning Authority.

Reason: To demonstrate that the site is suitable (or otherwise) for the use of infiltration techniques as part of the drainage strategy.

Respective Condition Notes

1. The scheme shall include the utilisation of holding sustainable drainage techniques with the incorporation of sufficient treatment trains to maintain or improve the existing water quality; the limitation of surface water run-off to equivalent greenfield rates; the ability to accommodate surface water run-off on-site up to the critical 1 in 100 year return period event plus an appropriate allowance for climate change, based upon the submission of drainage calculations.

Full details for the drainage proposal should be supplied including, but not limited to; construction details, cross sections, long sections, headwall details, pipe protection details (e.g. trash screens), and full modelled scenarios for event durations up to the 24 hour (or longer where required) for the 1 in 1 year, 1 in 30 year and 1 in 100 year plus climate change return periods with results ideally showing critical details only for each return period.

2. Details should demonstrate how surface water will be managed on site to prevent an increase in flood risk during the various construction stages of development from initial site works through to completion. This shall include temporary attenuation, additional treatment, controls, maintenance and protection. Details regarding the protection of any proposed infiltration areas should also be provided.
3. Details of the surface water Maintenance Plan should include for routine maintenance, remedial actions and monitoring of the separate elements of the surface water drainage system that will not be adopted by a third party and will remain outside of individual property ownership. For commercial properties (where relevant), this should also include procedures that must be implemented in the event of pollution incidents.
4. The results of infiltration testing should conform to BRE Digest 365 Soakaway Design. The LLFA would accept the proposal of an alternative drainage strategy that could be used should infiltration results support an alternative approach. Where infiltration is deemed viable, proposed infiltration structures must be designed in accordance with CIRIA C753 "The SuDS Manual" or any superseding version of this guidance.

Advice to the Local Planning Authority

1. Standing Advice – National Planning Policy Framework

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding where informed by a site-specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be

undertaken in accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

2. Standing Advice – Consent

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted. Guidance on this process and a sample application form can be found via the following website: <http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

This consent does not consider local watercourse bylaws. It is the responsibility of the applicant to check if the local borough or district council has their own bylaws which the proposals will also need to consider.

3. Standing Advice – Maintenance

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of Environment and Transport.