

From: public.access@hinckley-bosworth.gov.uk
Sent: 31 January 2025 13:14
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 25/00008/HOU

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 31/01/2025 1:13 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	25/00008/HOU
Address:	Merton House Grove Road Burbage Hinckley Leicestershire LE10 2AD
Proposal:	Erection of two single storey garden buildings, including associated works.
Case Officer:	Richard Wright

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the outbuilding roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	---

Kind regards