

**From:** public.access@hinckley-bosworth.gov.uk <public.access@hinckley-bosworth.gov.uk>  
**Sent:** 18 December 2025 12:11:00 UTC+00:00  
**To:** "Planning Application Comments" <planningapplicationcomments@hinckley-bosworth.gov.uk>  
**Subject:** Consultee Comments for Planning Application 25/01169/FUL  
**Categories:** Yasmin

## Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 18/12/2025 12:10 PM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

### Application Summary

Reference:	25/01169/FUL
Address:	Peggs Close Earl Shilton Leicestershire
Proposal:	Erection of 15 houses and 6 flats with associated parking and landscaping
Case Officer:	Ashleigh Gade

[Click for further information](#)

### Comments Details

I have the following comments and recommendations:

#### Land contamination

The Phase I Risk Assessment recommends that further intrusive works are carried out to characterise the site, including a landfill gas risk assessment. This may be conditioned.

#### Comments:

#### Construction

I recommend a CEMP is conditioned to manage the environmental impacts of the development during the construction phase.

#### Recommended conditions:

#### C174. Land Contamination

a) No development approved by this permission shall be commenced until a scheme for the investigation of any potential

land contamination on the site has been submitted to and agreed in writing by the Local Planning Authority which shall include details of how any contamination shall be dealt with.

b) The approved scheme shall be implemented in accordance with the agreed details and any remediation works so approved shall be carried out prior to the site first being occupied.

#### NTA 50 - Contaminated Land (1)

In relation to conditions X and X advice from Environmental Health should be sought via [esadmin@hinckley-bosworth.gov.uk](mailto:esadmin@hinckley-bosworth.gov.uk) to ensure that any investigation of land contamination is in accordance with their policy.

#### C75. Land Contamination Found Later

a) If during development, contamination not previously identified is found to be present at the site, no further development shall take place until an addendum to the scheme for the investigation of all potential land contamination is submitted to and approved in writing by the Local Planning Authority which shall include details of how the unsuspected contamination shall be dealt with.

b) Any remediation works so approved shall be carried out prior to the site first being occupied.

#### C77. Landfill Gas Scheme

a) No development approved by this permission shall be commenced until a scheme for the monitoring of landfill gas on the site has been submitted to and agreed in writing by the Local Planning Authority which shall include details of how any landfill gas shall be dealt with.

b) The approved scheme shall be implemented in accordance with the agreed details and any remediation works so approved shall be carried out prior to the site first being occupied.

### CONSTRUCTION

a) Prior to commencement of development a Construction Environmental Management Plan shall be submitted to and agreed in writing by the LPA. The plan shall detail how, during the site preparation and construction phase of the development, the impact on existing and proposed residential premises and the environment shall be prevented or mitigated from dust, odour, noise, smoke, light and land contamination. The plan shall detail how such controls will be monitored. The plan will provide a procedure for the investigation of complaints.

b) The agreed details shall be implemented throughout the course of the development.

Site preparation and construction shall be limited to the following hours;

Monday – Friday 07:30 – 18:00

Saturday 08:00 – 13:00

No working on Sundays and Bank Holidays

---

Kind regards