

From: public.access@hinckley-bosworth.gov.uk
Sent: 29 January 2024 10:52
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00078/HOU

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 29/01/2024 10:51 AM from Mr Simon Smith (simon.smith@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 1.

Application Summary

Reference:	24/00078/HOU
Address:	90 Northfield Road Hinckley Leicestershire LE10 0LJ
Proposal:	Installation of air source heat pump to rear elevation
Case Officer:	Sophie Iliffe

[Click for further information](#)

Comments Details

Comments:	It needs to be detailed which model is to be used so that the exact specification can be identified. It also needs to be detailed at what distance the noise levels in the specification have been calculated at.
	In addition, can the distance between the unit and the neighbouring fences and neighbouring windows be provided please.

Kind regards