

Application address Logistics Ltd Unit G Fleming Road Hinckley Leicestershire		Planning ref.	26/00439/FUL
		Our ref.	2026/0439/04/F
Description Change of use from B8 storage or distribution to mixed use B2 General Industrial & B8 storage or distribution		Consultation date	14/07/2026
		Response date	04/08/2026
Planning officer	Sophie Iliffe	Reviewing officer	Danielle Degville
Application type	Change of Use	Extension requested	☐
Refer to standing advice ☒	Conditions ☐	Further consultation required ☐	Concerns ☐

Consultation checklist

No.	Description	Check
1	Location plan	☒
2	Proposed layout plan	☒
3	Evidence that the site can be drained	☒
4	Topographic and ground investigation details	☒
5	The total impermeable area pre and post development	☒
6	All potential flood risk sources have been identified and assessed	☒
7	Existing and proposed peak discharge rates	☒
8	Consideration of sustainable drainage systems	☒
9	Attenuation volume calculations	☒
10	Consideration of the maintenance and management of all drainage elements	☒

LLFA Key Observations and Advice

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that the brownfield site is located within Flood Zone 2 and 3 being at medium-high risk of fluvial flooding and a low to medium risk of surface water flooding.

The proposals are for change of use and do not increase impermeable areas on site. The LLFA has no concerns regarding these proposals.

Leicestershire County Council as the LLFA advises the LPA that the proposed development is considered to be acceptable based on the surface water management principles provided within the application. The development should be designed in accordance with the details provided.

Advice to the Local Planning Authority

1. Standing Advice – National Planning Policy Framework

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding where informed by a site-specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be undertaken in accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

2. Standing Advice – Consent

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted. Guidance on this process and a sample application form can be found via the following website: <http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

This consent does not consider local watercourse bylaws. It is the responsibility of the applicant to check if the local borough or district council has their own bylaws which the proposals will also need to consider.

3. Standing Advice – Maintenance

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of the Growth, Environment and Transport Department.