



CDM Regulations:
In addition to any information included in this drawing or the model from which it is derived, refer also to the project CDM Risk Register for information on residual risks.

- General Notes:
- The drawing does not necessarily show all the information needed to interpret the design intent or the construction details.
 - The drawing contains information from more than one source and must be read in conjunction with all relevant specifications.
 - Any apparent drafting errors and differences between other drawings and specifications shall be brought to our attention.

Project Notes:

- LEGEND:
- EX1 HOLOPHANE D-SERIES 0 AREA LUMINAIRE. 21W, 3030 lm OR EQUAL AND APPROVED. COLUMN MOUNTED AT 5m.
 - EX2 THORLUX PASSWAY PATHWAY BOLLARD LUMINAIRE. 11W, 780 lm OR EQUAL AND APPROVED.

- ISOLINES:
- 1 LUX
 - 2 LUX
 - 4 LUX
 - 6 LUX
 - 8 LUX
 - 10 LUX
 - 12 LUX
 - 14 LUX
 - 16 LUX
 - 18 LUX
 - 20 LUX
 - 22 LUX

P01	STAGE 4 ISSUE	JH	MAB	CS	FEB'24
Index	Description	Designed	Reviewed	Authorised	Date

REVISIONS:

HOARE LEA 

ARCHITECT:
THE DESIGN BURO

CLIENT:
NHS PROPERTY SERVICES

PROJECT TITLE:
HINCKLEY CDC & ENDOSCOPY

DRAWING TITLE:
Hinckley CDC Enabling Works
Electrical Services
External Lighting Isolines Layout

STAGE 4

PERSON RESPONSIBLE FOR:		
Design: JH	Review: MAB	Authorising Issue: CS

Project No: 0104181	Date: FEBRUARY 2024	Scale @ A1: 1:200
------------------------	------------------------	----------------------

DRAWING NUMBER:	Status:	Rev:
0104181-HLEA-XX-XX-DR-E-708002	S2	P01

EXTERNAL REFERENCES DRG No's
20240221 - DBC1782-08C-ENB-00-DR-A-0650 P03 Proposed Site Plan