PLANNING APPLICATION COMMENT SHEET

	08/01156/FUL	**14 Merrylees Road Newbold Verdon**
16.12.2008	**CTF**	**ERECTION OF NO TWO HOUSES**
DEL		**Applicant : Mr Darren Webb**
		Ward : Newbold Verdon With Desford & Peckleton

ENVIRONMENTAL SERVICES COMMENTS.

Surface water should be discharged to a soakaway, subject to satisfactorily permeable ground strata.

Access drives, parking and turning areas should be constructed in a pervious paving system, with or without attenuation storage, depending on ground strata permeability.

C Brown
Land drainage Engineer
Date: 13/01/09

SIGNATURE: DATE