Denise Stone

From: planning@hinckley-bosworth.gov.uk
Posted At: 17 August 2009 10:57
Conversation: ConsulteeAccess for Planning - Application Comments (09/00590/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00590/FUL)

ConsulteeAccess for Planning - Application Comments (09/00590/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 17/08/2009 10:56:50 from IP 192.168.0.3.

Application Summary

Application Number:
09/00590/FUL

Address:
47 Priesthills Road
Hinckley
Leicestershire
LE10 1AQ

Proposal:
EXTENSION AND ALTERATIONS TO PROVIDE TWO EXTRA BEDROOMS

Case Officer:
James Hicks

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
The suitability of the ground strata for soakaway drainage should be ascertained by means of the test described in BRE Digest 365, and the results approved by the Building Control Surveyor before development is commenced. The soakaway must be constructed either as a brick or concrete-lined perforated chamber with access for maintenance or, alternatively, assembled from units of one of the newer, modular systems, comprising cellular tanks and incorporating silt traps. Design and construction of all types of soakaway will be subject to the approval of the Building Control Surveyor.