Denise Stone

From: planning@hinckley-bosworth.gov.uk
Posted At: 17 August 2009 10:44
Conversation: ConsulteeAccess for Planning - Application Comments (09/00585/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00585/FUL)

ConsulteeAccess for Planning - Application Comments (09/00585/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 17/08/2009 10:43:40 from IP 192.168.0.3.

Application Summary

Application Number:
09/00585/FUL

Address:
95 Hinckley Road
Stoke Golding
Nuneaton
Leicestershire
CV13 6ED

Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING.

Case Officer:
Louise Forman

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@huinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet. (See Environment Agency guidance on the permeable surfacing of front gardens)

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.