

From: public.access@hinckley-bosworth.gov.uk <public.access@hinckley-bosworth.gov.uk>
Sent: 10 June 2026 10:14:01 UTC+01:00
To: "PF - Planning" <planningapplications@hinckley-bosworth.gov.uk>
Subject: Consultee Comments for Planning Application 26/00319/OUT
Categories: Yasmin

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 10/06/2026 10:14 AM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

Application Summary

Reference:	26/00319/OUT
Address:	Land Adjacent Colwyn Main Street Botcheston Leicestershire
Proposal:	Outline planning application for 26 new dwellings with all matters reserved
Case Officer:	Joe Fleetwood

[Click for further information](#)

Comments Details

Comments:	Land contamination I recommend a condition is applied to any permission granted to require that land contamination is considered. This is due to the potential for past agricultural use of the site to have led to contamination of the soils.
	Construction I recommend a CEMP is conditioned to manage the environmental impacts of the development during the construction phase.
	Recommended conditions: C174. Land Contamination a)No development approved by this permission shall be commenced until a scheme for the investigation of any potential land contamination on the site has been submitted to and agreed in writing by the Local Planning Authority which shall include details of

how any contamination shall be dealt with.

b) The approved scheme shall be implemented in accordance with the agreed details and any remediation works so approved shall be carried out prior to the site first being occupied.

NTA 50 - Contaminated Land (1)

In relation to conditions X and X advice from Environmental Health should be sought via esadmin@hinckley-bosworth.gov.uk to ensure that any investigation of land contamination is in accordance with their policy.

C75. Land Contamination Found Later

a) If during development, contamination not previously identified is found to be present at the site, no further development shall take place until an addendum to the scheme for the investigation of all potential land contamination is submitted to and approved in writing by the Local Planning Authority which shall include details of how the unsuspected contamination shall be dealt with.

b) Any remediation works so approved shall be carried out prior to the site first being occupied.

CONSTRUCTION

a) Prior to commencement of development a Construction Environmental Management Plan shall be submitted to and agreed in writing by the LPA. The plan shall detail how, during the site preparation and construction phase of the development, the impact on existing and proposed residential premises and the environment shall be prevented or mitigated from dust, odour, noise, smoke, light and land contamination. The plan shall detail how such controls will be monitored. The plan will provide a procedure for the investigation of complaints.

b) The agreed details shall be implemented throughout the course of the development.

Site preparation and construction shall be limited to the following hours;

Monday – Friday 07:30 – 18:00

Saturday 08:00 – 13:00

No working on Sundays and Bank Holidays

Kind regards

This email and any files sent with it are confidential. If this email isn't intended for you, please notify the sender immediately and then permanently delete it. You must not read, print, store, disclose, copy or take any other action in respect of this email. We routinely monitor incoming and outgoing email messages to ensure they comply with Hinckley & Bosworth Borough Council's policy on the use of electronic communications. The contents of emails may have to be disclosed to a request under the Data Protection Act 2018, Freedom of Information Act 2000 and/or the Environmental Information Regulations 2004. The views expressed by the author may not necessarily reflect the views or policies of Hinckley & Bosworth Borough Council. Attachments to email messages may

contain viruses that may damage your system. Whilst Hinckley & Bosworth Borough Council has taken every reasonable precaution to minimise this risk, we cannot accept any liability for any damage you suffer as a result. You are advised to carry out your own virus checks before opening any attachment. Save paper - only print this email if necessary. Visit us online: www.hinckley-bosworth.gov.uk Main office: Hinckley Hub, Rugby Road, Hinckley, Leics LE10 0FR