

Application address Land Adjacent to Hinckley Rugby Club Leicester Road Hinckley Leicestershire LE10 3DR		Planning ref.	23/01135/FUL
		Our ref.	2023/1135/04/F/R1
Description Construction of two storey boxing gym with associated parking, outdoor activity areas and landscaping		Consultation date	13/03/2024
		Response date	27/03/2024
Planning officer	Alex Jelley	Reviewing officer	Andrew Smallwood
Application type	Full	Extension requested	☐
Refer to standing advice ☐	Conditions ☒	Further consultation required ☐	Concerns ☐

Consultation checklist

No.	Description	Check
1	Location plan	☒
2	Proposed layout plan	☒
3	Evidence that the site can be drained	☒
4	Topographic and ground investigation details	☒
5	The total impermeable area pre and post development	☒
6	All potential flood risk sources have been identified and assessed	☒
7	Existing and proposed peak discharge rates	☒
8	Consideration of sustainable drainage systems	☒
9	Attenuation volume calculations	☒
10	Consideration of the maintenance and management of all drainage elements	☒

LLFA Key Observations and Advice

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that the 0.33ha greenfield site is located within Flood Zone 1 being at low risk of fluvial flooding and a low risk of surface water flooding.

The submission now contains surface water drainage details at this stage, these drainage details are sufficient for the size and scale of the development in relation to the low risk of surface water flooding on site.

Leicestershire County Council as Lead Local Flood Authority (LLFA) advises the Local Planning Authority (LPA) that the proposals are considered acceptable to the LLFA and we advise the following planning conditions be attached to any permission granted.

Advised Conditions

1. No development approved by this planning permission shall take place until such time as a surface water drainage scheme has been submitted to, and approved in writing by the Local Planning Authority. The development must be carried out in accordance with these approved details and completed prior to first occupation.

Reason: To prevent flooding by ensuring the satisfactory storage and disposal of surface water from the site.

2. No development approved by this planning permission shall take place until such time as details in relation to the management of surface water on site during construction of the development has been submitted to, and approved in writing by the Local Planning Authority. The construction of the development must be carried out in accordance with these approved details.

Reason: To prevent an increase in flood risk, maintain the existing surface water runoff quality, and to prevent damage to the final surface water management systems through the entire development construction phase.

Respective Condition Notes

1. The scheme shall include the utilisation of holding sustainable drainage techniques with the incorporation of sufficient treatment trains to maintain or improve the existing water quality; the limitation of surface water run-off to equivalent greenfield rates; the ability to accommodate surface water run-off on-site up to the critical 1 in 100 year return period event plus an appropriate allowance for climate change, based upon the submission of drainage calculations.

Full details for the drainage proposal should be supplied including, but not limited to; construction details, cross sections, long sections, headwall details, pipe protection details (e.g. trash screens), and full modelled scenarios for event durations up to the 24 hour (or longer where required) for the 1 in 1 year, 1 in 30 year and 1 in 100 year plus climate change return periods with results ideally showing critical details only for each return period.

Where there are changes to the surface water proposals which alter the maintenance requirements, a revised maintenance plan should be submitted.

2. Details should demonstrate how surface water will be managed on site to prevent an increase in flood risk during the various construction stages of development from initial site works through to completion. This shall include temporary attenuation, additional treatment, controls, maintenance and protection. Details regarding the protection of any proposed infiltration areas should also be provided.
-

Advice to the Local Planning Authority

1. Standing Advice – National Planning Policy Framework

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding where informed by a site specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be undertaken in accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

2. Standing Advice – Consent

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted. Guidance on this process and a sample application form can be found via the following website: <http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

This consent does not consider local watercourse bylaws. It is the responsibility of the applicant to check if the local borough or district council has their own bylaws which the proposals will also need to consider.

3. Standing Advice – Maintenance

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

4. Standing Advice – Minor works

If a proposed building/wall or other construction appears to sit astride an indicated surface water flow route, the new build may deflect floodwater onto another person's property or raise flood levels by a significant amount locally. In these circumstances, the planning officer should contact the County Council to discuss whether consultation is necessary in that particular case.

5. Standing Advice – Greenfield Development Runoff

For greenfield sites, the peak runoff rate from the development to any drain, sewer or surface water body for the 1 in 1 year rainfall event and the 1 in 100 year rainfall event should never exceed the peak greenfield runoff rate for the same event.

The runoff volume from the development in the 1 in 100 year, 6 hour rainfall event should not exceed the greenfield runoff volume for the same event. Where an increase in discharge volume is unavoidable, the proposals should discharge at QBar or provide alternative mitigation in line with CIRIA C753.

6. Standing Advice – Drainage and waste disposal

Where a drainage or waste disposal system is to be constructed or altered that is not proposed to be adopted by either the WASC (Water and Sewerage Company) or the County Council as

highway authority then the system should be constructed in accordance with Part H of Building Regulations 2010.

7. Standing Advice – Overland flow routes

Overland flow routes as shown on the 'extent of flooding from surface water' maps should be considered such that buildings are not placed directly at risk of surface water flooding. Such flow routes should be utilised for roads and green infrastructure.

8. Standing Advice – Ditches

Where a drainage ditch adjoins or flows through a development, provision should be made such that the ditch can be made throughout the life of the development. The ownership and responsibility for maintenance of the ditch should also be clearly identified and conveyed to the relevant parties.

9. Standing Advice – External surfaces

To prevent an increase in the discharge rate or volume due to development of external surfaces, permeable surface material should be utilised where possible, without an impermeable lining unless required to prevent mobilisation of contaminants or groundwater flooding.

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of Environment and Transport.