
From: public.access@hinckley-bosworth.gov.uk
Sent: 10 May 2024 16:06
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00357/FUL

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 10/05/2024 4:06 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/00357/FUL
Address:	Weston Bosworth Road Carlton Nuneaton Leicestershire CV13 0BX
Proposal:	Demolition of existing garage and construction of a new skincare treatment room with associated access and car park
Case Officer:	Joe Fleetwood

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the proposed outbuilding roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	--

Kind regards