

ODOUR IMPACT ASSESSMENT

EMAQ, (2018) Control of Odour and Noise from
Commercial Kitchen Exhaust Systems,
(amendment DEFRA, 2005)

Commercial Odour




NOISE
ASSESSMENTS LTD
YOUR LOCAL ACOUSTIC SPECIALIST

REPORT DETAILS

Report Title	Odour Assessment: Commercial Extraction
Site Address	57 Wood St, Earl Shilton, Leicester, LE9 7NE
Project No.	NALPRO101125.01a
Consultant Contact	jonathan@noiseassessments.co.uk

QUALITY ASSURANCE

Issue No.	Status	Issue Date	Comments	Author	Approved
1	FINAL	15/03/26	-		
2	FINAL	09/04/26	Updated based on council comments	J Mape BSc (Hons) PgDip, Consultant	D Warren Director

This report has been prepared by Noise Assessments the trading name of Noise Assessments Limited, with all reasonable skill, care and diligence within the terms of the Contract with the client, incorporating our General Terms and Conditions of Business and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above.

This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

Noise Assessments Limited – Companies House Registered No. 12207511

Contents

Assessment Summary	1
1. Proposal	2
2. Existing Context.....	2
3. Policy and Guidance.....	2
4. Nearest Sensitive Receptor Locations.....	3
5. Odour Assessment	3
6. Odour Impact Assessment	5
7. The Odour Management Plan.....	6
8. Air changes per hour and Efflux Velocity.....	8
9. Summary	8
APPENDIX A – Site Location	10
APPENDIX B – Classification of Odour and Grease Content of Extract Air from Commercial Kitchens	12
APPENDIX C – EMAQ Odour Impact Risk Assessment Methodology	14
APPENDIX D – Specification for ESP System	15

Assessment Summary

A ground floor commercial property applying to operate as a pizza/burger style restaurant/cafe seeks planning permission for its extraction system for the change of use of an existing premises (formerly a barber shop, to a Class E(b) restaurant/café to confirm that its external flue meets odour control guidelines. The client has completed an odour assessment at 57 Wood St, Earl Shilton, Leicester LE9 7NE.

An odour assessment is required to assess the likely impact from odour generated during the cooking process from the extraction system within the rear of the site which will have the air vented at ground floor level to exit the ground floor terminating 2m above the eaves at 15m/s during the daytime.

The environmental health department of the local planning authority is likely to have concerns of odour emissions from the use of the extraction fan unit on neighbouring sensitive residential properties.

If the recommendations are followed, odour should not impact nearby residences. Implementing the OMP recommendations as "best practicable means" will prevent statutory nuisance.

With regular maintenance, the extraction system is unlikely to cause odour problems.

1. Proposal

- 1.1 A ground floor commercial property applying to operate as a pizza/burger style restaurant/cafe seeks planning permission for its extraction system for the change of use of an existing premises (formerly a barber shop, to a Class E(b) restaurant/café to confirm that its external flue meets odour control guidelines. The client has completed an odour assessment at 57 Wood St, Earl Shilton, Leicester LE9 7NE.
- 1.2 An odour assessment is required to assess the likely impact from odour generated during the cooking process from the extraction system within the rear of the site which will have the air vented at ground floor level to exit the ground floor terminating 2m above the eaves at 15m/s during the daytime.
- 1.3 The environmental health department of the local planning authority will raise concerns of odour emissions from the use of the extraction fan unit on neighbouring sensitive residential properties.

2. Existing Context

- 2.1 The site (ground floor level) is set within a commercial row of 2-storey attached buildings. The site is surrounded by residential apartments and commercial unit, adjacent to a main road.
- 2.2 The environmental health department of the local planning authority is likely to raise concerns of odour emissions from the use of the fan extraction unit venting on sensitive residential properties.

3. Policy and Guidance

Odour Technical Guidance

- EMAQ, (2018) Control of Odour and Noise from Commercial Kitchen Exhaust Systems, an amendment of the original DEFRA document published in 2005, deals specifically with the control of kitchen odours.
 - Guidance on the Assessment of Odour for Planning, Version 1.1 Institute of Air Quality Management (IAQM), 2018. The IAQM published the 'Guidance on the Assessment of Odour for Planning' document in July 2018. This guidance specifically deals with assessing odour impacts for planning purposes, namely potential effects on amenity.
- 3.1 The magnitude of odour impact depends on a number of factors and the potential for adverse impacts varies due to the subjective nature of odour perception. The FIDOL acronym is a useful reminder of the factors that can be used to help determine the degree of odour pollution:
 - Frequency of detection - frequent odour incidents are more likely to result in adverse impacts;

- Intensity as perceived - intense odour incidents are more likely to result in adverse impacts;
- Duration of exposure - prolonged exposure is more likely to result in adverse impacts;
- Offensiveness - more offensive odours have a higher risk of resulting in adverse impacts; and,
- Receptor sensitivity - (The type of land use and nature of human activities in the vicinity of an odour source. Tolerance and expectation of the receptor.)

3.2 It is important to note that even infrequent emissions of odours may cause loss of amenity if odours are perceived to be particularly intense or offensive.

4. Nearest Sensitive Receptor Locations

4.1 The nearest sensitive receptors (NSRs) have been identified as a residential apartment within 20 meters of the site, above.

5. Odour Assessment

Introduction

5.1 This odour assessment relates to the potential future odour emanating from any kitchen extraction system associated with the change of use development, and the potential odour impacts on any sensitive receptors near the extract flue.

Nature and Effect of Odour

5.2 Odour is perceived by our brains in response to chemicals present in the air we breathe. Odour is the effect that those chemicals have upon us. Humans have sensitive senses of smell, and they can detect odour even when chemicals are present in very low concentrations. Most odours are a mixture of many chemicals that interact to produce what we detect as an odour.

5.3 Different life experiences and natural variation in the population can result in different sensations and emotional responses by individuals to the same odorous compounds. Because the response to odour is synthesised in our brains, other senses such as sight and taste, and even our upbringing, can influence our perception of odour and whether we find it acceptable, objectionable, or offensive.

Assessment Methodology

5.4 The assessment of odour takes on the following aspects:

- A qualitative assessment of proposed odour emissions from the change of use development;
- An assessment taking into account the nature of the premises;
- The height and position of any proposed flue;
- The recommended exit velocity from the flue; and

- The distance between the proposed flue and the potential odorous emissions and the distance to the sensitive receptor.

Guidance on Control of Odours from Kitchens

- 5.5 The Department for Environment Food and Rural Affairs (DEFRA) originally published Guidance (now withdrawn) on the control of odours from kitchens. That guidance has been subsequently updated by 'Control of Odour and Noise from Commercial Kitchen Exhaust Systems' (EMAQ, July 2018).
- 5.6 Although the guidance is not statutory, it provides very useful information on best practice techniques for the minimisation of odour nuisance from kitchen exhaust systems. This source of guidance and ACCON's own experience form the basis of the assessment to determine whether nearby occupiers of existing residential properties would consider that odour emanating from the kitchen extract flue is acceptable or not.

General Principles in Controlling Odour

- 5.7 The guidance is generally used for premises where food is cooked for patrons on or off the premises and where a kitchen is used to prepare and cook food. In these instances, a kitchen canopy extract system, are invariably present.
- 5.8 The main purpose of a kitchen canopy is to extract excess heat, steam, fats, smoke and odour arising from cooking processes. Removal of these unwelcome by-products of kitchen activity helps to achieve a reasonably comfortable and safe working environment, protect the working environment, as well as preventing the spread of the products from the kitchen area to other parts of the building.
- 5.9 Odours from cooking are contained both within the solid, liquid and gaseous material which is extracted by the kitchen canopy, and these different phases generally require different abatement techniques to reduce levels of odour to those levels which are acceptable to those in the vicinity. The extent to which any odour mitigation is required is dependent on the type of foods being prepared and cooked.
- 5.10 Commonly the kitchen extract canopy will contain the first line of odour control through the incorporation of coarse grease filters, which take out the largest grease particles from the extracted air stream. Such coarse grease filters tend to be a common feature of almost all kitchen canopy systems.
- 5.11 The type and levels of odour control required downstream of the canopy is very much dependent on a number of factors. The principle ones are:
- Type of food prepared. This is probably the most dominant factor as the type of food, and particularly any spices used, dictates the chemical constituents present in the exhaust air;

- Size of the cooking facility. The number of covers (for these premises, as no dining is included, the important aspect is the amount of general food output from the kitchen); and
- Types of cooking appliances used. This dictates the level of fat, water droplets and temperature within the ventilation air

5.12 The guidance includes two Tables which classify the odour and grease content of extract air according to the general cooking type and equipment used. These are reproduced in Appendix 3 (Table 2A and Table 2B). The information, in Appendix 3, has been used in this report to carry out the odour risk assessment in respect of the consented change of use development.

6. Odour Impact Assessment

6.1 Based on the location of the external extraction system, this odour impact assessment and Odour Management Plan has been undertaken in accordance with the EMAQ guidance 'Control of Odour and Noise from Commercial Kitchen Exhaust Systems'.

Risk Assessment

6.2 The guidance provides a means of risk assessing the impact of any catering establishment and proposed and existing uses. The key elements of the method are reproduced in Appendix 3. The method relies on scoring the proposal on four different aspects:

- **Dispersion** – where the extract vents to atmosphere are in relation to the building to which the vent is attached.
- **Proximity of receptors** – the location of the nearest residents;
- **The kitchen size** – number of covers, i.e. level of activity; and
- **Cooking type** – based on grease and odour loading.

6.3 The level of odour which is created by a premises will depend on the size of kitchen and type of cooking. These can be determined using categories which have been set out in the guidance and are replicated in Appendix 4.

6.4 The scores for each aspect are summed to derive an overall significance score, an impact risk, and a statement about the odour control requirement. The guidance has been utilised where possible to determine the risk of odour nuisance from the proposed change of use development, without any additional odour abatement in place.

6.5 The risk assessment provided in Table 1, is a worst-case scenario.

Table 1: Odour Risk Assessment – 57 Wood St, Earl Shilton, Leicester, LE9 7NE.

	Descriptor	Score	Impact Risk	Odour Control Requirement
Dispersion	Moderate	10	High	High level odour control
Proximity of Receptors	Close	10		
Size of kitchen/food cooking area	Medium	3		
Cooking Type (Odour & grease loading)	Very High	10		
Total		33		

6.6 For the proposed flue extract system, discharging above the eaves (Moderate, Score 10). There are receptors within 20m of the proposed flue extract (Close, Score 10).

6.7 The kitchen will be Medium, more than 30 covers or small sized restaurant (Medium, Score 3).

6.8 There will be British/European (Type of food include burgers, pizzas and process mostly by grill, and oven) cooking to take place at the premises. Therefore, the cooking type (odour and grease loading) is classed as Very High (Very High, Score 10).

6.9 The results of the overall assessment are potentially a **High Risk** with low level odour control.

7. The Odour Management Plan

7.1 Section 7 states that, even with recommendations followed, the development presents a 'Low' risk of nuisance and would typically require minimum odour mitigation.

Proposed Ventilation and Extraction System

7.2 The proposals are for the external flue exiting to above the eaves. The mitigation requirements which are:

1. Electrostatic Precipitator (ESP) followed by carbon filtration (carbon filter with a 0.2 – 0.4 residence time).

- 7.3 The ESP has been specifically designed for kitchen extract systems and have integral sumps to collect the oil, grease and smoke particles filtered out of the exhaust. This not only simplifies servicing but eradicates potentially dangerous spillage from the bottom of the units and this cuts down on the buildup of grease within the ducting.

Maintenance Programme (Type, Frequency and Regime)

- 7.4 To minimize the risk of complaints, it is recommended that:

- A visual inspection of the ventilation system be carried out at least once a week. All metal surfaces should be checked to ensure that there is no accumulation of grease or dirt and that there is no surface damage;
- Cooker hoods and grease filters should be cleaned on a daily basis;
- Baffle type self-draining filters and collection drawers should be cleaned weekly, as a minimum. The cleaning period for mesh filters should be at least twice a week;
- Cleaning period for extract ductwork should as follows:

Use	No. hours use per day	Minimum cleaning interval
Heavy use	12-16	Every 3 months
Moderate use	6-12	Every 6 months
Light use	2-6	Annually

- 7.5 Based on the information provided, it is likely that the premises will be of Light to Moderate Use and should be cleaned at least every 6 months.

- Periodic 'deep hygiene cleaning' should be undertaken by a specialist contractor. All accessible main ductwork runs and branches, including fitted equipment should be inspected and cleaned.
- All fans are to be maintained on a regular basis as recommended by the fan manufacturer; and
- Ventilation grilles, where fitted should have easily removable cores to facilitate cleaning.

Recommendations for maintenance of odour control system

- 7.6 Carbon filtration;

- Change fine filters every two weeks
- Change carbon filters every 4 to 6 months

- 7.7 For the ESP system:

- Clean every 2-6 months

- 7.8 An Autowash nozzle attachment sited inside the standard ESP units. The control / wash station collection cells can be automatically cleaned on a regular frequency.
- 7.9 Daily cleaning keeps the filters working at their optimum efficiency and will greatly reduce the number of service visits required throughout the year.
- 7.10 It will be important that the odour control methods are fully implemented and additionally, that the proposed OMP management measures and frequency of servicing is complied with. With respect to the servicing and maintenance regime, audit and service records should be maintained and made available to the Local Authority on demand.

Extraction System

- 7.11 The proposed extract fan is an acoustically lined ventilation complete with intake and extract spigots and with flexible connectors to reduce vibration transmission. It will be installed on Anti-vibration mountings, one for each corner of the fan unit to mitigate any risk of vibration transmission to the neighbouring properties.

8. Air changes per hour and Efflux Velocity

- 8.1 Design volume: $1.28\text{m}^3/\text{s}$ (canopy hood overall design volume) $\times 3600 = 4,608\text{m}^3/\text{hr}$.
- 8.2 Prep kitchen and cook area $3\text{x}6\text{x}3\text{m} = 54\text{m}^3$. Recommended air change rate for commercial kitchen is 60 ac/hr.
- 8.3 The air change rate equates to $4,608\text{m}^3/\text{hr}$ divided by the room volume 54m^3 . This gives an air change rate of 85 ac/hr. The minimum for commercial kitchen 15-30 ac/hr. this rate can be brought down using the speed regulator.

Efflux Velocity

- 8.4 The following calculation shows how the system will meet the 15-16m/s velocity.

$$0.45\text{x}0.45 = 0.1590\text{m}^2 \text{ (air across duct section)}$$

$$1.28\text{m}^3/\text{s} / 0.07794 \text{ (free area inside 315dia duct)} = \underline{16.42\text{m/s efflux velocity}}.$$

9. Summary

- 9.1 With respect to odour, it has been identified that providing that the recommendations are taken into account, there should not be a loss of amenity at the existing residential receptors in the vicinity of the extraction flue and as long as the system similar to the ones recommended in the OMP are implemented, this would consist of using the "best practicable means" and would prevent statutory nuisance occurring.


- 9.2 If the extraction system is properly maintained on a regular basis, it is highly unlikely that odour would become an issue.

Appendices

APPENDIX A – Site Location



Site location



APPENDIX B – Classification of Odour and Grease Content of Extract Air from Commercial Kitchens

Table 2A: Table detailing the grease and odour content of various types of food

Catering establishment	Description	Odour content				Grease content			
		Low	Moderate	High	Very high	Low	Moderate	High	Very high
Tea shop									
Pizza restaurant	Herb								
Steakhouses	Fat								
French	Herbs/garlic								
Italian	Herbs/garlic								
Most pubs	Fat								
Chinese	Ginger, spices, oil								
Japanese	Spices, oil								
Cantonese	Spices, oil								
Indian	Spices, oil								
Thai	Spices, oil								
Vietnamese	Spices, oil								
Kebab	Fat cooking meat								
Fried Chicken	Oil, cooking meat								
Pubs (fried)	Oil, cooking meat								
Fish & chip	Oil								
Fast food, burger	Oil, cooking meat								

Table 2B: Table detailing the grease & moisture content of various cooking appliances

Cooking appliance	Grease loading			Moisture content		
	Light	Medium	Heavy	Light	Medium	Heavy
Cooking pots						
Bains Marie						
Steam ovens						
Pizza ovens						
Bratt pans						
Oven ranges						
Flat top grills						
Chip fryers						
Salamanders						
Charcoal						
Gas fired open grills						
Char boilers						
Chinese wok ranges						

APPENDIX C – EMAQ Odour Impact Risk Assessment Methodology

Odour control must be designed to prevent odour nuisance in a given situation. The following score methodology is suggested as a means of determining odour control requirements using a simple risk assessment approach.

Impact Risk	Odour Control Requirement	Significance Score*
Low to medium	Low level odour control	<20
High	High level odour control	20-35
Very high	Very high level odour control	>35

*based on the sum of contributions from dispersion, proximity of receptors, size of kitchen and cooking type.

Criteria	Descriptor	Score	Details
Dispersion	Very poor	20	Low level discharge, discharge into courtyard or restriction on stack.
	Poor	15	Not low level but below eaves, or discharge at below 10m/s
	Moderate	10	Discharging 1m above eaves at 10-15m/s
	Good	5	Discharging 1m above ridge at 15m/s
Proximity of receptors	Close	10	Closest sensitive receptor less than 20 m from kitchen discharge
	Medium	5	Closest sensitive receptor between 20-100m from kitchen discharge
	Far	1	Closest sensitive receptor greater than 100m from kitchen discharge
Size of kitchen Cooking type (odour and grease loading)	Large	5	More than 100 covers or large sized restaurant
	Medium	3	Between 30-100 covers or medium sized restaurant
	Small	1	Less than 30 covers or small restaurant
	Very high	10	Pub (high level of fried food), fried chicken, burgers or fish and chips
	High	7	Kebab, Vietnamese, Thai or Indian
	Medium	4	Cantonese, Japanese or Chinese
	Low	1	Most pubs, Italian, French, pizza or steakhouse

APPENDIX D – Specification for ESP System

Electrostatic Precipitation (ESP) Filter Unit



Technical Specifications

There are currently four models in the range:

- ESP 1500EI, which contains a single ESP Collector Cell.
- ESP 3000EI, which contains two ESP Collector Cells.
- ESP 4500EI, which contains three ESP Collector Cells.
- ESP 6000EI, which contains four ESP Collector Cells.

The specification of each model is detailed below:

	ESP 1500EI	ESP 3000EI	ESP 4500EI	ESP 6000EI
Power consumption	20 Watts	30 Watts	40 Watts	50 Watts
Maximum air handling capacity	Up to 0.7m ³ /sec	Up to 1.4m ³ /sec	Up to 2.1m ³ /sec	Up to 2.8m ³ /sec
Dimensions	W 450mm H 630mm D 640mm	W 900mm H 630mm D 640mm	W 1350mm H 630mm D 640mm	W 1800mm H 630mm D 640mm
Weight	55kg	85kg	118kg	153kg
Power supply	220/240V 50Hz 1ph	220/240V 50Hz 1ph	220/240V 50Hz 1ph	220/240V 50Hz 1ph
Filter efficiency	Up to 98%	Up to 98%	Up to 98%	Up to 98%
Housing	Epoxy-coated galvanised steel	Epoxy-coated galvanised steel	Epoxy-coated galvanised steel	Epoxy-coated galvanised steel

Sitesafe Carbon Filters

We manufacture Sitesafe carbon filters, these innovative carbon units measure 594x196x597mm, three combining to 594x594x597mm, directly replacing our original carbon blocks whilst providing exactly the same filter performance as an existing full size cell.

Their advantage is that they only weigh 18kg each against the 68kg of our original blocks. This takes the strain out of fitting and servicing, allowing only one engineer to complete the task where two had been previously required.

Our Sitesafe carbon filters use panels of activated carbon to remove the malodorous gases within the commercial kitchen extract duct through the process of chemical adsorption. By installing our ESP units before our Sitesafe filters, the carbon life span is greatly increased, allowing it to nullify malodours at optimum efficiency for much longer.

Will require two people plus lifting gear to carry and install.



Carbon PA242424

Size 594x594x597
Gross Weight 68.20kg
Carbon Weight 50.00kg
Rated Airflow 3600m³/hr*
Pressure Drop 120Pa

Safe for one person to carry. No special lifting gear required.



Sitesafe PA240824

Size 594x196x597
Gross Weight 17.95kg
Carbon Weight 16.6kg
Rated Airflow 1200m³/hr*
Pressure Drop 120Pa



Sitesafe 3 x PA240824

Size 594x594x597
Gross Weight 53.85kg
Carbon Weight 50.00kg
Rated Airflow 3600m³/hr*
Pressure Drop 120Pa



Please see below for the recommended minimum dwell times required for different applications and scale up accordingly.

It should be noted that filtration performance will be improved by increasing the dwell times applied.

Application	Recommended Dwell Time	Grade
Cooking - Low Odour, Tea Shop, Canteens	0.1 to 0.2 Seconds	Carbon grade Enhanced for improved performance for light catering odours
Cooking - Moderate Odour, Pizza, Steak House, French, Italian, Pubs, Chinese, Japanese, Cantonese	0.2 to 0.4 Seconds	Enhanced Carbon grade suitable for many applications 65% Minimum CTC
Cooking High Odour, Indian, Thai, Vietnamese, Kebab	0.4-0.6 Seconds	Enhanced Carbon grade suitable for many applications 65% Minimum CTC
Cooking Very High Odour, Fried Chicken, Pubs with large fried food turnover, Fish and Chip Shops, Fast Food / Burgers	0.4-0.8 Seconds	Enhanced Carbon grade suitable for many applications 65% Minimum CTC
Reduction of Kerosene Exhaust fumes	0.1 to 0.2 Seconds	General Purpose Activated Carbon
Reduction of Ozone	0.1 to 0.2 Seconds	General Purpose Activated Carbon
Reduction of Diesel Fumes, including H ₂ S, SO ₂ , NOX, HCl	0.2 Seconds	Carbon Museum, Archive, Café Directive: SO ₂ SOX NO ₂ NOX Removal
Museum and Archives	0.2 Seconds	Carbon Museum, Archive, Café Directive: SO ₂ SOX NO ₂ NOX Removal

The cooking odour classes above are as classified by DEFRA in **Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems, PB10527**

ABOUT US

HERE TO HELP

We undertake various noise assessments and noise survey for a wide range of clients to meet their noise requirements and obligations, including for Planning Applications, new developments, building extensions, change of use, small businesses, restaurants, shops and much more.

QUALIFIED AND EXPERIENCED

Over 15 years UK and international acoustic engineering experience of undertaking Noise Monitoring, acoustic solutions, noise survey and Reporting.

Members of the Institute of Acoustics. Undertaken projects in Manchester, North West and across the UK.

GET THE PROJECT DONE

We offer competitive, cost effective acoustic solutions, delivering a noise survey report which complies with Local Planning Authority requirements and sound insulation or health and safety obligations.

We can also undertake Noise Modelling if required.