Denise Stone

From: planning@hinckley-bosworth.gov.uk
Posted At: 25 August 2009 12:27
Conversation: ConsulteeAccess for Planning - Application Comments (09/00581/DEEM)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00581/DEEM)

ConsulteeAccess for Planning - Application Comments (09/00581/DEEM)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 25/08/2009 12:26:51 from IP 192.168.0.3.

Application Summary

Application Number:
09/00581/DEEM

Address:
Land Adj
H L P Warehouse
Bridge Road
Burbage
Leicestershire

Proposal:
RESIDENTIAL DEVELOPMENT (OUTLINE - ALL MATTERS RESERVED)

Case Officer:
Eleanor Shaw

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:
Customer wishes to comment on the Planning Application.

Comments:
Surface water should be discharged to a soakaway subject to satisfactorily permeable ground strata.

Access drives, parking and turning areas, paths and patios should be constructed in a

permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.