Louise Forman

From: Tracy Miller
Sent: 12 March 2008 11:00
To: Louise Forman
Subject: FW: Planning App. 0701486. Nos. 82-84 Leicester Road, Hinckley

Louise

Just in case you haven't got a copy on file

Tracy

-----Original Message-----
From: Robert.Higgins@severntrent.co.uk [mailto:Robert.Higgins@severntrent.co.uk]
Sent: 11 March 2008 16:32
To: Tracy Miller
Cc: Bill-Networks.Walton@severntrent.co.uk; Lydie.Melvin@severntrent.co.uk
Subject: Planning App. 0701486. Nos. 82-84 Leicester Road, Hinckley

Tracy

With reference to our earlier telephone conversation, I can respond as follows:-

Severn Trent Water currently oppose the above proposed development due to the lack of available spare capacity in the nearby existing public sewers, and flooding problems emanating from the public sewerage systems in the vicinity, which have affected some dwellings in close proximity to the application site.

Severn Trent Water will only withdraw the drainage objection subject to paragraphs 1 or 2 as follows, being satisfied:-

The site redevelopment is carried out following completion of flood alleviation schemes proposed by this Company, however the current projected dates for which may be subject to change and the provision of funding.
The Developer/Agent can satisfy Severn Trent Water that the site redevelopment can be achieved without any increase in the current foul and surface water discharges to public sewers from the application site, i.e. from the existing 2 no. dwellings on the site.

Severn Trent Water have a duty and obligation to protect our existing Customers from the increased risk of public sewer flooding, should the development proceed before the required public sewer improvements are carried out.

Severn Trent Water responded on the 20th February 2008 to the Developer's Agent, via our Drainage Statement No. WT 17538, and we are awaiting the submission of drainage proposals in accordance with the requirements of this Statement.

Hope this is ok for you.

Regards

Robert Higgins
Asset Protection
Severn Trent Water

STW Ref. WT 17538

****
Severn Trent Water Limited is a limited company registered in England and Wales under registered number 2366686 with its registered office at 2297 Coventry Road, Birmingham B26 3PU;

Severn Trent Retail and Utility Services Limited is a limited company registered in

England and Wales under registered number 2562471 with its registered office at 2297 Coventry Road, Birmingham B26 3PU;

Complete Credit Management Limited is a limited company registered in England and Wales under registered number 4690658 with its registered office at 2297 Coventry Road, Birmingham B26 3PU;

("the Companies")

This e-mail (which includes any files attached to it) is not contractually binding on its own, it is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 (0)121 722 4000.
If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this e-mail. Please note that the Companies reserve the right to monitor email communications in accordance with applicable law and regulations.

To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this e-mail including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies.