

---

**From:** public.access@hinckley-bosworth.gov.uk  
**Sent:** 24 March 2025 14:07  
**To:** Planning Application Comments  
**Subject:** Consultee Comments for Planning Application 24/01066/FUL

## Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 24/03/2025 2:07 PM from Mr Peter Reid ([peter.reid@hinckley-bosworth.gov.uk](mailto:peter.reid@hinckley-bosworth.gov.uk)) on behalf of HBBC Drainage.

### Application Summary

Reference:	24/01066/FUL
Address:	Land West Of Westfield Avenue Earl Shilton Leicestershire
Proposal:	Erection of 18 dwellings with associated access, car parking, landscaping and drainage
Case Officer:	Matt Jedruch

[Click for further information](#)

### Comments Details

Comments:	As previously indicated, there is an issue with provision of the attenuation tank within the private parking bays of plots 5 to 7 - to ensure the long term maintenance and operational integrity of the drainage system, any SuDS elements serving the whole development should be located within publicly accessible areas
-----------	--

Kind regards