

From: public.access@hinckley-bosworth.gov.uk <public.access@hinckley-bosworth.gov.uk>
Sent: 03 December 2025 11:24:22 UTC+00:00
To: "Planning Application Comments" <planningapplicationcomments@hinckley-bosworth.gov.uk>
Subject: Consultee Comments for Planning Application 25/01097/FUL
Categories: Yasmin

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 03/12/2025 11:24 AM from Mr Simon Smith (simon.smith@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 1.

Application Summary

Reference:	25/01097/FUL
Address:	5 Pymm Ley Gardens Groby Leicester Leicestershire LE6 0FU
Proposal:	Demolition of existing dwelling and erection of a self-build dwelling
Case Officer:	Joe Fleetwood

[Click for further information](#)

Comments Details

Comments:	The application states that an air source heat pump will be installed. Location details need to be submitted, along with the specification of the pump so that potential impact from noise can be considered.
-----------	---

Kind regards