
From: public.access@hinckley-bosworth.gov.uk
Sent: 09 December 2024 15:06
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/01079/OUT

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 09/12/2024 3:06 PM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

Application Summary

Reference:	24/01079/OUT
Address:	Land North Of Station Road Market Bosworth Nuneaton Leicestershire
Proposal:	Outline planning application for up to 126 dwellings (all matters reserved except access)
Case Officer:	Sullevan Archer

[Click for further information](#)

Comments Details

I have the following initial comments regarding the Noise Impact Assessment:

Comments:

With regard to potential industrial noise from JJ Churchill- Section 5.4 explains that no acoustic character correction has been applied to the rating level however the “doors open” scenario predicts that noise from the site would exceed the measured background level by 7dB/14dB (day/night- table 5.2). The operation in question is oil pan production from which I understand impact noise would be expected and character correction would be required. An increase in the rating level would increase the level of mitigation required in table 5.4. At the predicted levels in table 5.4 for plot X (and plot Y for daytime) indoor criteria is exceeded with windows open and an alternative ventilation strategy should be considered.

With regard to table 5.4 the daytime sound levels include both music noise breakout from the building and vehicles. What is the contribution of the music noise levels at plot Z?

Kind regards