

From: Planning.APEast <Planning.APEast@severntrent.co.uk>
Sent: 19 August 2026 12:03:54 UTC+01:00
To: "Ashleigh Gade" <Ashleigh.Gade@hinckley-bosworth.gov.uk>; "PF - Planning" <planningapplications@hinckley-bosworth.gov.uk>
Subject: Application: 25/01169/FUL Site: Peggs Close Earl Shilton Leicestershire

ST Classification: UNMARKED

For the attention of **Ashleigh Gade**

Our Ref: **P-251218-48339**

To whom it may concern,

Re Application: 25/01169/FUL

Re Site: Peggs Close Earl Shilton Leicestershire

With reference to the above planning application, the Company's observations are as follows.

Sustainable Development.

If the council is minded to approve the application, we ask that it first uses the planning powers available to it to ensure that the proposed development is built as sustainably as possible and does not harm the local environment or increase flood risk for those living downstream of the development.

Severn Trent has the capacity serve the development with drinking water and to safely take away all wastewater (subject to the above). The danger we want to avoid is the development increasing the amount of rain and surface water in our sewers (combined or foul), which increases flood risk for those living downstream, is environmentally damaging and pushes up costs for customers generally.

There is much developers can do to manage the rainwater onsite. They can, for example, build environment-boosting ponds and swales, make use of permeable paving or explore using lightly treated rainwater to flush toilets. Our website provides further information: [Sustainable Drainage Systems](#) | [Building sustainable homes](#) | [Building and developing](#) | [Severn Trent Water](#)

The critical point is that new developments should manage rainwater sustainably on site wherever possible.

Severn Trent requests that any approval be conditioned as follows:

- The development should not commence until drainage plans for the disposal of foul and surface water flows have been submitted to and approved by the Local Planning Authority.

- The plan should follow the principles of Planning Practice Guidance and section H of the Building Regulations 2010. The disposal of surface water by means of soakaways should be considered as the primary method.
- If this is not feasible and there is no watercourse available as an alternative, other sustainable methods should also be explored.
- The scheme shall be implemented in accordance with the approved details before the development is first brought into use.

No surface water to enter the foul or combined water systems by any means.

This more sustainable approach will benefit the environment, save money overall and reduce the flood risk faced by customers living downstream.

I should emphasise that we are not objecting to the development. Our point is that it should be built sustainably, if the council is minded to grant permission.

IMPORTANT NOTE: With regard to network capacity, this response only relates to the public waste water network and does not include representation from other areas of Severn Trent Water, such as the protection of drinking water quality.

Please note for the use or reuse of sewer connections either direct or indirect to the public sewerage system the applicant will be required to make a formal application to the Company under Section 106 of the Water Industry Act 1991. They may obtain copies of our current guidance notes and application form from either our website (www.stwater.co.uk) or by contacting our Developer Services Team (Tel: 0800 707 6600).

Suggested Informative – affected sewers and water mains

Before undertaking any work on site, all applicants must determine if Severn Trent has any assets in the vicinity of the proposed works. This can be done by accessing our records at www.digdat.co.uk

Severn Trent Water advise that even if our statutory records do not show any public sewers within the area you have specified, there may be sewers that have been recently adopted under The Transfer of Sewer Regulations 2011.

Public sewers and Water mains have statutory protection and may not be built close to, or diverted without consent, consequently you must contact Severn Trent Water to

discuss your proposals. Severn Trent will seek to assist you obtaining a solution which protects both the public sewer and the proposed building.

Please see attached our Standard Guidance for your information.

Additional information

If the development site includes a Vehicle Wash / Petrol Station / Swimming Pool / Industrial Processes, or anything else that may discharge waste other than foul sewage or surface water into the public network, we would strongly recommend the applicant speaks to the Trade Effluent Support Team before requesting a discharge of any drainage related condition. The team can be contacted by email:

trade.effluent@severntrent.co.uk

Should you require any further information please contact us on email below.

Yours sincerely,

Severn Trent

Asset Protection Team

Planning.apeast@severntrent.co.uk

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ. This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain confidential, commercially sensitive or may be covered by legal professional privilege. If you are not the intended recipient, you must not disclose or use the information contained in it. If you have received this message in error, please notify the sender immediately or call us on 03457 500 500. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email.