
From: public.access@hinckley-bosworth.gov.uk
Sent: 16 October 2024 12:49
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00921/HOU

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 16/10/2024 12:49 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/00921/HOU
Address:	33 King Richard Road Hinckley Leicestershire LE10 0HJ
Proposal:	Single storey rear extension and timber garden building
Case Officer:	Sophie Iliffe

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the detached outbuilding roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	--

Kind regards