

From: public.access@hinckley-bosworth.gov.uk
Sent: 16 October 2024 12:25
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00879/HOU

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 16/10/2024 12:24 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/00879/HOU
Address:	Beech Court Rectory Lane Cadeby Nuneaton Leicestershire CV13 0RB
Proposal:	Two storey front and rear extension, single storey rear extension, conversion of existing garage, new brick slips and render and new detached garage/storage building.
Case Officer:	Richard Wright

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the detached garage roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	---

Kind regards