

From: David Spring
Sent: 04 October 2024 10:07
To: Planning Folder New
Subject: FW: Market Bosworth School - Fw: 24/00403/FUL - acoustic report, amended IMP7664-2

From: Giles Rawdon <Giles.Rawdon@hinckley-bosworth.gov.uk>
Sent: 04 October 2024 09:34
To: David Spring <David.Spring@hinckley-bosworth.gov.uk>
Subject: RE: Market Bosworth School - Fw: 24/00403/FUL - acoustic report, amended IMP7664-2

Hi David

Thanks for the update. The NIA is predicting acceptable noise levels with the suggested mitigation in place (a 2.5m Acoustic Screen in place as proposed on the detailed drawings. The screen should be continuous in length, have no gaps, be sealed to the ground and have a minimum mass of 14kg/m2).

Provided the mitigation is carried out I have no objection but would recommend a condition requiring the fence and that this is maintained in perpetuity.

Kind regards

Giles Rawdon
Environmental Health Officer
(Environmental Protection)
Tel: 01455 255684
Email: giles.rawdon@hinckley-bosworth.gov.uk
Web: www.hinckley-bosworth.gov.uk
Hinckley Hub, Rugby Road, Hinckley, Leics LE10 0FR



Sign up for our email updates: www.hinckley-bosworth.gov.uk/emailupdates



@Hinckandbos_bc



Hinckandbosbc



@Hinckandbosbc

From: David Spring <David.Spring@hinckley-bosworth.gov.uk>
Sent: 27 September 2024 12:27
To: Giles Rawdon <Giles.Rawdon@hinckley-bosworth.gov.uk>
Subject: FW: Market Bosworth School - Fw: 24/00403/FUL - acoustic report, amended IMP7664-2

Hi Giles,

Please see an amended noise impact assessment attached and email below. I just received it today so hopefully you haven't spent time going through the previous version.

I look forward to hearing your comments in due course.

With thanks,

David

From: [REDACTED]
Sent: 27 September 2024 12:20
To: David Spring <David.Spring@hinckley-bosworth.gov.uk>
Cc: [REDACTED]
Subject: Re: Market Bosworth School - Fw: 24/00403/FUL - acoustic report, amended IMP7664-2

Hello David,

We now have the amended and final report from Impact Acoustics, attached.

We queried the timing of the base-line assessment which was carried out over a bank holiday, ie. no noise levels for the pupils at play. Apparently this make little difference to the basic calculations.

We also queried the options for mitigating against the perceived increase in noise. In particular, we did not want to lower the level of the MUGa into more of the 'natural ground', having informed the County Archaeologist that this was minimal.

We also want to make sure we do not get into a situation where the baffle screen for the residences is itself a problem to them due to the height. So, the solution we think is to go with a 2.5m high screen mounted on the ball-stop fence of the MUGA south-west corner area, as noted in the report (see section 6.4)

Please forward this to the Pollution Officer, to replace the previous version.

Thanks & regards,

David

[REDACTED]