Louise Forman

From: Paul Marsden
Sent: 22 July 2010 17:26
To: Louise Forman
Subject: RE: Document

Louise,

I have had a look through the attached report and feel that they have fully and accurately described the structural condition of the barn. They have identified that the rear foundations will require underpinning and will need to submit a proposed scheme for that portion of the works. Also, they have indicated that the gable may need to be rebuilt is it is felt that repair as stated in the report is considered unsuitable / sufficient to fully repair the gable wall.

On the whole the report seems sufficiently comprehensive of the building in its current state.

Regards

Paul

-----Original Message-----
From: Louise Forman
Sent: 19 July 2010 15:55
To: Paul Marsden
Subject: Document

Paul

Could you check this report for me please.

Thanks

Louise