
From: public.access@hinckley-bosworth.gov.uk
Sent: 11 June 2024 11:52
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00488/HOU

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 11/06/2024 11:51 AM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/00488/HOU
Address:	Kirkby Old Parks Farm Kirkby Lane Newbold Verdon Leicester Leicestershire LE9 9LN
Proposal:	Two-storey side extension, creation of balcony, demolition and replacement of ancillary outbuilding and construction of a double garage (Retrospective)
Case Officer:	Richard Wright

[Click for further information](#)

Comments Details

Note to applicant:

Comments:	Rainwater discharged from the detached garage roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, rather than discharge directly onto the surface of the application site and neighbouring gardens.
-----------	---

Kind regards