

From: public.access@hinckley-bosworth.gov.uk
Sent: 23 January 2025 15:39
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 25/00005/DISCON

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 23/01/2025 3:39 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	25/00005/DISCON
Address:	Twycross Zoological Park Burton Road Norton Juxta Twycross Atherstone Leicestershire CV9 3PX
Proposal:	Application to discharge C3 (Updated Bat Survey) C4 (Great Crested Newt Survey Results), C5 (Biodiversity Net Gain Plan), C6 (Land Contamination Scheme), C8 (Surface Water Drainage Scheme), C9 (Surface Water during Constructio), C11 (Arboricultural site monitoring) attached to planning permission 24/00838/CONDIT
Case Officer:	Lesley Keal

[Click for further information](#)

Comments Details

Comments:	C8 - SuDS details satisfactory in principle, supporting hydraulic calculations should be submitted for review
	C9 - no details of surface water management during construction have been submitted

Kind regards