## Denise Stone

**From:** planning@hinckley-bosworth.gov.uk
**Posted At:** 14 September 2009 09:54
**Conversation:** ConsulteeAccess for Planning - Application Comments (09/00647/FUL)
**Posted To:** Planning Application Comments

**Subject:** ConsulteeAccess for Planning - Application Comments (09/00647/FUL)

ConsulteeAccess for Planning - Application Comments (09/00647/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 14/09/2009 09:54:22 from IP 192.168.0.3.

Application Summary
---
Application Number:
09/00647/FUL

Address:
29 Spa Lane
Hinckley
Leicestershire
LE10 1JA

Proposal:
EXTENSIONS AND ALTERATIONS TO GARAGE TO PROVIDE OCCUPATIONAL THERAPY SUITE AND ERECTION OF DETACHED GARDEN ROOM.

Case Officer:
Louise Forman

Customer Details
---
Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments
---
Submission Type:

Comments:
The suitability of the ground strata for soakaway drainage should be ascertained by means of the test described in BRE Digest 365, and the results approved by the Building Control Surveyor before development is commenced. The soakaway must be constructed either as a brick or concrete-lined perforated chamber with access for maintenance or, alternatively, assembled from units of one of the newer, modular systems, comprising cellular tanks and incorporating silt traps. Design and

construction of all types of soakaway will be subject to the approval of the Building Control Surveyor.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.