
From: public.access@hinckley-bosworth.gov.uk
Sent: 23 May 2024 11:27
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00395/HOU
Categories: Sonia

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 23/05/2024 11:26 AM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

Application Summary

Reference:	24/00395/HOU
Address:	84 Shenton Lane Market Bosworth Nuneaton Leicestershire CV13 0PN
Proposal:	Installation of air source heatpump
Case Officer:	Richard Wright

[Click for further information](#)

Comments Details

Comments:	The unit has failed the MCS-20 criteria and some form of noise control will be required. can the applicant provide details of proposed noise control please (information may be available from the manufacturer/supplier)?
-----------	--

Kind regards