

**From:** public.access@hinckley-bosworth.gov.uk <public.access@hinckley-bosworth.gov.uk>  
**Sent:** 17 August 2026 15:54:34 UTC+01:00  
**To:** "PF - Planning" <planningapplications@hinckley-bosworth.gov.uk>  
**Subject:** Consultee Comments for Planning Application 26/00666/FUL

## Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 17/08/2026 3:54 PM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

### Application Summary

|               |                                                                                                |
|---------------|------------------------------------------------------------------------------------------------|
| Reference:    | 26/00666/FUL                                                                                   |
| Address:      | Market Bosworth Parish Hall 25 Park Street Market Bosworth<br>Nuneaton Leicestershire CV13 0LL |
| Proposal:     | Installation of 2 x wall mounted air conditioning units and solar panels to roof slopes        |
| Case Officer: | Sophie Iliffe                                                                                  |

[Click for further information](#)

### Comments Details

My comments submitted 28.07.26 stand:

I have some concerns relating to noise from the external air conditioning units.

Comments:

Can the applicant please provide an assessment of noise. The Fujitsu ASEH36KMTB/AOEH36KMTB is an air source heat pump (air-to-air), and MCS 020(a) is the relevant noise assessment standard. The assessment is not necessarily a Noise Impact Assessment requiring an acoustic consultant and the supplier should be able to assist with this.

Should the appliances fail the MCS 020(a) noise assessment revised guidance is available from the CIEH/IOA (Air Source Heat Pumps Professional Advice Note (2026)) and a level 1 assessment should be carried out.

Kind regards

This email and any files sent with it are confidential. If this email isn't intended for you, please notify the sender immediately and then permanently delete it. You must not read, print, store, disclose, copy or take any other action in respect of this email. We routinely monitor incoming and outgoing email messages to ensure they comply with Hinckley & Bosworth Borough Council's policy on the use of electronic communications. The contents of emails may have to be disclosed to a request under the Data Protection Act 2018, Freedom of Information Act 2000 and/or the Environmental Information Regulations 2004. The views expressed by the author may not necessarily reflect the views or policies of Hinckley & Bosworth Borough Council. Attachments to email messages may contain viruses that may damage your system. Whilst Hinckley & Bosworth Borough Council has taken every reasonable precaution to minimise this risk, we cannot accept any liability for any damage you suffer as a result. You are advised to carry out your own virus checks before opening any attachment. Save paper - only print this email if necessary. Visit us online: [www.hinckley-bosworth.gov.uk](http://www.hinckley-bosworth.gov.uk) Main office: Hinckley Hub, Rugby Road, Hinckley, Leics LE10 0FR