Tiffany MacDonald

From: planning@hinckley-bosworth.gov.uk
Posted At: 16 March 2009 12:47
Conversation: ConsulteeAccess for Planning - Application Comments (09/00177/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00177/FUL)

ConsulteeAccess for Planning - Application Comments (09/00177/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 16/03/2009 12:46:41 from IP 192.168.0.3.

Application Summary

Application Number:
09/00177/FUL

Address:
Linton Farm
Merrylees Road
Thornton
Leicestershire

Proposal:
ERECTION OF GENERAL PURPOSE AGRICULTRAL BUILDING

Case Officer:
Richard Wright

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
[redacted]

Phone Number:

Comments

Submission Type:

Comments:
It is noted that the applicant does not intend to use the building as a cover to an existing slurry lagoon indefinitely. If he plans to house livestock in the proposed building following the drainage of the lagoon, provision shall be made to ensure that animal waste and surface water contaminated by animal waste will not be discharged to ditches, watercourses or soakaways. Slurry, contaminated runoff - including wash water - and leachate from stockpiled manure, must be collected in tanks (or lagoons) complying with the standards laid down in the 'Control of Pollution (Silage, Slurry

and Agricultural Fuel Oil) Regulations 1991'. Clean roof water should be discharged to soakaways (subject to suitable ground strata), ditches or watercourses.

It would be helpful if the applicant could indicate how future provision for slurry storage will be arranged; there are no site layout plans on the file for guidance in this regard

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.