Tiffany MacDonald

From: planning@hinckley-bosworth.gov.uk
Posted At: 16 March 2009 15:04
Conversation: ConsulteeAccess for Planning - Application Comments (09/00163/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00163/FUL)

ConsulteeAccess for Planning - Application Comments (09/00163/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 16/03/2009 15:04:14 from IP 192.168.0.3.

Application Summary

Application Number:
09/00163/FUL

Address:
23 Burton Road
Twycross
Coalville
Leicestershire
CV9 3PR

Proposal:
ERECTION OF TEAROOM AND TOILET BLOCK BUILDINGS

Case Officer:
James Hicks

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
[redacted]

Phone Number:

Comments

Submission Type:

Comments:
Is waste water to be discharged to the public system? If not, what method will be used? A package treatment plant or a septic tank would require the approval of the Environment Agency, and a cesspit would need to be sited so that it is accessible to a road tanker - which would require turning facilities.

If these issues are satisfactorily dealt with on the application form (not included

with the planning file documents), no comments.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.