Lisa Clarke

From: planning@hinckley-bosworth.gov.uk
Posted At: 02 November 2010 16:47
Conversation: ConsulteeAccess for Planning - Application Comments (10/00855/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (10/00855/FUL)

ConsulteeAccess for Planning - Application Comments (10/00855/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00855/FUL "Chris Brown" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address.
A summary of your comments is provided below.
Comments were submitted at 02/11/2010 16:46:56 from chris.brown@hinckley-bosworth.gov.uk
Application Summary

Application Number: 10/00855/FUL
Address:
Land Adjacent
3 Mill Drive
Ratby
Leicester
Leicestershire
LE6 0JH
Proposal:
ERECTION OF 1NO. DWELLING
Case Officer:
Sarah Fryer
Customer Details

Name:
Chris Brown
Address:
empty
Comments:
Unless the slope of the site prohibits it, access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet - in this case the public surface water sewer.
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.