

From: public.access@hinckley-bosworth.gov.uk <public.access@hinckley-bosworth.gov.uk>
Sent: 26 March 2026 12:26:36 UTC+00:00
To: "PF - Planning" <planningapplications@hinckley-bosworth.gov.uk>
Subject: Consultee Comments for Planning Application 26/00195/FUL
Categories: Yasmin

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 26/03/2026 12:26 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	26/00195/FUL
Address:	Land At Inglenook Farm Leicester Road Barwell Leicester Leicestershire LE9 8BD
Proposal:	Erection of two holiday lodges and associated works
Case Officer:	Ashleigh Gade

[Click for further information](#)

Comments Details

Notes to applicant:

Comments: Surface water should be managed by sustainable methods, preferably those which disperse runoff by infiltration into the ground strata: i.e. soakaways, pervious paving, filter drains, swales, etc. and the minimisation of paved area, subject to satisfactory porosity test results and the site being free from a contaminated ground legacy. If the ground strata are insufficiently permeable to avoid discharging some surface water off-site, flow attenuation methods should be employed, either alone or in combination with infiltration systems and/or rainwater harvesting systems.

Any proposed access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may

be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet (See Environment Agency guidance on the permeable surfacing of front gardens).

Kind regards

This email and any files sent with it are confidential. If this email isn't intended for you, please notify the sender immediately and then permanently delete it. You must not read, print, store, disclose, copy or take any other action in respect of this email. We routinely monitor incoming and outgoing email messages to ensure they comply with Hinckley & Bosworth Borough Council's policy on the use of electronic communications. The contents of emails may have to be disclosed to a request under the Data Protection Act 2018, Freedom of Information Act 2000 and/or the Environmental Information Regulations 2004. The views expressed by the author may not necessarily reflect the views or policies of Hinckley & Bosworth Borough Council. Attachments to email messages may contain viruses that may damage your system. Whilst Hinckley & Bosworth Borough Council has taken every reasonable precaution to minimise this risk, we cannot accept any liability for any damage you suffer as a result. You are advised to carry out your own virus checks before opening any attachment. Save paper - only print this email if necessary. Visit us online: www.hinckley-bosworth.gov.uk Main office: Hinckley Hub, Rugby Road, Hinckley, Leics LE10 0FR