



**RESPONSE OF THE LEAD LOCAL FLOOD AUTHORITY TO CONSULTATION BY HINCKLEY & BOSWORTH BOROUGH COUNCIL**

<b>Application address</b> Wiggs Farm Wood Road Nailstone Coalville Leicestershire	<b>Planning ref.</b> 25/00523/FUL		
	<b>Our ref.</b> 2025/0523/04/F/R1		
<b>Description</b> The erection of a B8 distribution hub with ancillary offices, quality control office and canopy, maintenance units, and gatehouse, and associated infrastructure and landscaping	<b>Consultation date</b> 08/08/2025		
	<b>Response date</b> 20/08/2025		
<b>Planning officer</b> Matt Jedruch	<b>Reviewing officer</b> Danielle Degville		
<b>Application type</b> Full	<b>Extension requested</b> <input type="checkbox"/>		
<b>Refer to standing advice</b> <input type="checkbox"/>	<b>Conditions</b> <input type="checkbox"/>	<b>Further consultation required</b> <input checked="" type="checkbox"/>	<b>Concerns</b> <input type="checkbox"/>

**Consultation checklist**

No.	Description	Check
1	Location plan	<input checked="" type="checkbox"/>
2	Proposed layout plan	<input checked="" type="checkbox"/>
3	Evidence that the site can be drained	<input type="checkbox"/>
4	Topographic and ground investigation details	<input checked="" type="checkbox"/>
5	The total impermeable area pre and post development	<input checked="" type="checkbox"/>
6	All potential flood risk sources have been identified and assessed	<input checked="" type="checkbox"/>
7	Existing and proposed peak discharge rates	<input checked="" type="checkbox"/>
8	Consideration of sustainable drainage systems	<input checked="" type="checkbox"/>
9	Attenuation volume calculations	<input checked="" type="checkbox"/>
10	Consideration of the maintenance and management of all drainage elements	<input checked="" type="checkbox"/>

**LLFA Key Observations and Advice**

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that the 12.6ha greenfield site is located within Flood Zone 1 being at low risk of fluvial flooding and a low to high risk of surface water flooding. The proposals seek to discharge at 54.9 l/s via pervious paving, cellular attenuation tanks and an attenuation pond to the pond on nearby land.

New updated documents and drawings have been submitted for review. Whilst they answer most of the previously requested points there are still 2 points which need further clarification.

The point of discharge for the site is the pond within neighbouring land. No information has been provided on whether the developer has permission to discharge into this pond from the landowner. There has also been no information provided on the capacity of this pond and its downstream connectivity. This information is required to ensure that this point of discharge is suitable.

The Drainage Strategy section 4.3 suggest a watercourse to the south of the site, the LLFA is unsure where this watercourse is located as there doesn't appear to be a watercourse bounding the site. The photos show evidence of a drainage ditch however it is not clear where this is located.

---

Leicestershire County Council as Lead Local Flood Authority (LLFA) advises the Local Planning Authority (LPA) that the application documents as submitted are insufficient for the LLFA to provide a substantive response at this stage. In order to provide a substantive response, the following information is required:

- Confirmation of approval to discharge into the nearby pond, and information regarding the pond capacity and downstream connectivity
- Confirmation of location of the southern boundary watercourse

---

## **Advice to the Local Planning Authority**

### **1. Standing Advice – National Planning Policy Framework**

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding where informed by a site-specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be undertaken in accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

### **2. Standing Advice – Consent**

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted. Guidance on this process and a sample application form can be found via the following website: <http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

This consent does not consider local watercourse bylaws. It is the responsibility of the applicant to check if the local borough or district council has their own bylaws which the proposals will also need to consider.

### **3. Standing Advice – Maintenance**

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

---

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

*Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of Environment and Transport.*