

From: public.access@hinckley-bosworth.gov.uk
Sent: 29 June 2023 15:06
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 23/00567/CONDIT

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 29/06/2023 3:05 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	23/00567/CONDIT
Address:	The Acorns 236 Ashby Road Hinckley Leicestershire LE10 1SW
Proposal:	Variation of Condition 2, 10 and 11 of planning permission 21/00130/FUL (Planning Appeal ref: APP/K2420/W/21/3288892). Amendment to relocate garage and replace Appeal Approved Drawings ref: 1882-SP-002C and 1882-SP-007B (visibility splay) with new revision Drawings ref: 1882-SP-002D and 1882-SP-007C.
Case Officer:	David Spring

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the detached garage roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	---

Kind regards