

Plot	Room	Schedule	Fan l/s
Plot 001 - Kingfisher - Southeast	Bedroom1	Noise - Closed Night	-
Plot 001 - Kingfisher - Southeast	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 001 - Kingfisher - Southeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 001 - Kingfisher - Southeast	KitchenLiving	-	-
Plot 001 - Kingfisher - Southeast	Living	-	-
Plot 002 - Jackdaw - Southeast	Bedroom1	Noise - Closed Night	-
Plot 002 - Jackdaw - Southeast	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 002 - Jackdaw - Southeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 002 - Jackdaw - Southeast	Kitchen	-	-
Plot 002 - Jackdaw - Southeast	Living	-	-
Plot 003 - Jackdaw - Southeast	Bedroom1	Noise - Closed Night	-
Plot 003 - Jackdaw - Southeast	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 003 - Jackdaw - Southeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 003 - Jackdaw - Southeast	Kitchen	-	-
Plot 003 - Jackdaw - Southeast	Living	-	-
Plot 004 - Jackdaw - Southeast	Bedroom1	Noise - Closed Night	-
Plot 004 - Jackdaw - Southeast	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 004 - Jackdaw - Southeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 004 - Jackdaw - Southeast	Kitchen	-	-
Plot 004 - Jackdaw - Southeast	Living	-	-
Plot 005 - Jackdaw - Southeast	Bedroom1	Noise - Closed Night	10 l/s Extract Fan
Plot 005 - Jackdaw - Southeast	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 005 - Jackdaw - Southeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 005 - Jackdaw - Southeast	Kitchen	-	-
Plot 005 - Jackdaw - Southeast	Living	-	-
Plot 018 - Plover - Northeast	Bedroom1	Noise - Closed Night	35 l/s Extract Fan
Plot 018 - Plover - Northeast	Bedroom2	Noise - Closed Night	30 l/s Extract Fan
Plot 018 - Plover - Northeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 018 - Plover - Northeast	Bedroom4	Noise - Closed Night	20 l/s Extract Fan
Plot 018 - Plover - Northeast	KitchenLiving	-	-
Plot 018 - Plover - Northeast	Living	-	-
Plot 019 - Plover - Northeast	Bedroom1	Noise - Closed Night	30 l/s Extract Fan
Plot 019 - Plover - Northeast	Bedroom2	Noise - Closed Night	30 l/s Extract Fan
Plot 019 - Plover - Northeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 019 - Plover - Northeast	Bedroom4	Noise - Closed Night	20 l/s Extract Fan
Plot 019 - Plover - Northeast	KitchenLiving	-	-
Plot 019 - Plover - Northeast	Living	-	-
Plot 020 - Kingfisher - Northeast	Bedroom1	Noise - Closed Night	-
Plot 020 - Kingfisher - Northeast	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 020 - Kingfisher - Northeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 020 - Kingfisher - Northeast	KitchenLiving	-	-
Plot 020 - Kingfisher - Northeast	Living	-	-
Plot 021 - Jackdaw - East	Bedroom1	Noise - Closed Night	10 l/s Extract Fan
Plot 021 - Jackdaw - East	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 021 - Jackdaw - East	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 021 - Jackdaw - East	Kitchen	-	-
Plot 021 - Jackdaw - East	Living	-	-
Plot 022 - Jackdaw - East	Bedroom1	Noise - Closed Night	10 l/s Extract Fan
Plot 022 - Jackdaw - East	Bedroom2	Noise - Closed Night	20 l/s Extract Fan

Plot 022 - Jackdaw - East	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 022 - Jackdaw - East	Kitchen	-	-
Plot 022 - Jackdaw - East	Living	-	-
Plot 023 - Jackdaw - Southeast	Bedroom1	Noise - Closed Night	45 l/s Extract Fan
Plot 023 - Jackdaw - Southeast	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 023 - Jackdaw - Southeast	Bedroom3	Noise - Closed Night	30 l/s Extract Fan
Plot 023 - Jackdaw - Southeast	Kitchen	-	-
Plot 023 - Jackdaw - Southeast	Living	-	-
Plot 024 - Kingfisher - Southeast	Bedroom1	Noise - Closed Night	20 l/s Extract Fan
Plot 024 - Kingfisher - Southeast	Bedroom2	Noise - Closed Night	20 l/s Extract Fan
Plot 024 - Kingfisher - Southeast	Bedroom3	Noise - Closed Night	20 l/s Extract Fan
Plot 024 - Kingfisher - Southeast	KitchenLiving	-	-
Plot 024 - Kingfisher - Southeast	Living	-	-
Plot 061 - B1 - Southeast	Bedroom1	Security	10 l/s Extract Fan
Plot 061 - B1 - Southeast	KitchenLiving	-	-
Plot 062 - B1 - Southeast	Bedroom1	-	-
Plot 062 - B1 - Southeast	KitchenLiving	-	-
Plot 063 - B1 - Southeast	Bedroom1	-	-
Plot 063 - B1 - Southeast	KitchenLiving	-	-
Plot 064 - B1 - Southeast	Bedroom1	Security	10 l/s Extract Fan
Plot 064 - B1 - Southeast	KitchenLiving	-	-
Plot 086 - B1 - Northwest	Bedroom1	Security	-
Plot 086 - B1 - Northwest	KitchenLiving	-	-
Plot 087 - B1 - Northwest	Bedroom1	-	-
Plot 087 - B1 - Northwest	KitchenLiving	-	-
Plot 094 - B1 - West	Bedroom1	Security	15 l/s Extract Fan
Plot 094 - B1 - West	KitchenLiving	-	-
Plot 095 - B1 - West	Bedroom1	-	-
Plot 095 - B1 - West	KitchenLiving	-	-
Plot 096 - B1 - Northwest	Bedroom1	Security	-
Plot 096 - B1 - Northwest	KitchenLiving	-	-
Plot 097 - B1 - Northwest	Bedroom1	-	-
Plot 097 - B1 - Northwest	KitchenLiving	-	-
Plot 112 - B1 - Southwest	Bedroom1	-	-
Plot 112 - B1 - Southwest	KitchenLiving	-	-
Plot 113 - B1 - Southwest	Bedroom1	Security	-
Plot 113 - B1 - Southwest	KitchenLiving	-	-
Plot 114 - B1 - Northeast	Bedroom1	Security	-
Plot 114 - B1 - Northeast	KitchenLiving	-	-
Plot 115 - B1 - Northeast	Bedroom1	-	-
Plot 115 - B1 - Northeast	KitchenLiving	-	-
Plot 126 - B1 - Northwest	Bedroom1	Security	10 l/s Extract Fan
Plot 126 - B1 - Northwest	KitchenLiving	-	-
Plot 127 - B1 - Northwest	Bedroom1	-	-
Plot 127 - B1 - Northwest	KitchenLiving	-	-

Changes	A
	1.23
	1.62
	1.46
	1.66
	2.22
	0.8
	1.13
	0.88
	0.9
	1.31
	0.83
	1.11
	0.87
	0.9
	1.31
	0.83
	1.16
	0.87
	0.9
	1.36
	0.84
	1.13
	0.87
	0.91
	1.35
	0.9
	1.09
	1.18
	0.93
	1.49
	1.14
	0.93
	1.1
	1.16
	0.93
	1.61
	1.13
	1.34
	1.5
	1.24
	2.33
	1.59
	1.2
	1.11
	1.35
	1.66
	1.22
	1.23
	1.06

	1.36
	1.63
	1.19
	1.11
	1.06
	1.18
	1.51
	1.33
	1.44
	1.43
	1.37
	2.3
	1.72
	1.06
	1.32
	1.55
	2.5
	1.5
	2.02
	0.9
	1.06
	0.7
	1.43
	1.04
	2.54
	0.84
	1.27
	1.39
	2.01
	0.73
	1.42
	1.21
	2.18
	1.39
	2.31
	1.09
	1.24
	0.69
	1.57
	1.12
W-B1-07, W-B1-10 Double Casement Opening, W-B1-09 Triple Casement Opening	2.92
	1.01
	1.69
	1.65
	2.87

B	Result
28.83	Pass
25.33	Pass
26.67	Pass
N/A	Pass
N/A	Pass
26	Pass
23.5	Pass
25.83	Pass
N/A	Pass
N/A	Pass
28	Pass
23.67	Pass
25.67	Pass
N/A	Pass
N/A	Pass
26.67	Pass
22.17	Pass
26.5	Pass
N/A	Pass
N/A	Pass
26.17	Pass
22.83	Pass
26	Pass
N/A	Pass
N/A	Pass
30.67	Pass
29.67	Pass
26.5	Pass
27	Pass
N/A	Pass
N/A	Pass
32	Pass
28.33	Pass
26.5	Pass
27.5	Pass
N/A	Pass
N/A	Pass
22.67	Pass
26.83	Pass
28.83	Pass
N/A	Pass
N/A	Pass
24.17	Pass
26	Pass
31.33	Pass
N/A	Pass
N/A	Pass
30.17	Pass
25.5	Pass

31.33 Pass
N/A Pass
N/A Pass
29.5 Pass
26.83 Pass
26.17 Pass
N/A Pass
N/A Pass
27.67 Pass
26.17 Pass
26.17 Pass
N/A Pass
N/A Pass
27.33 Pass
N/A Pass
7.17 Pass
N/A Pass
9.17 Pass
N/A Pass
28 Pass
N/A Pass
29 Pass
N/A Pass
10.67 Pass
N/A Pass
31.17 Pass
N/A Pass
11.17 Pass
N/A Pass
31.33 Pass
N/A Pass
11.5 Pass
N/A Pass
6.83 Pass
N/A Pass
31.17 Pass
N/A Pass
29.83 Pass
N/A Pass
10.5 Pass
N/A Pass
29.33 Pass
N/A Pass
10.5 Pass
N/A Pass