
From: public.access@hinckley-bosworth.gov.uk
Sent: 04 July 2023 16:50
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 23/00606/FUL

Categories: Rudi

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 04/07/2023 4:49 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	23/00606/FUL
Address:	28 Charnwood Ratby Leicester Leicestershire LE6 0LD
Proposal:	Dropped kerb and vehicle access for parking
Case Officer:	Joseph Fleetwood

[Click for further information](#)

Comments Details

Notes to applicant:

Comments:	Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet (See Environment Agency guidance on the permeable surfacing of front gardens).
-----------	--

Kind regards