Amy Etchells

From: planning@hinckley-bosworth.gov.uk
Posted At: 06 January 2010 14:02
Conversation: ConsulteeAccess for Planning - Application Comments (09/00960/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00960/FUL)

ConsulteeAccess for Planning - Application Comments (09/00960/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 09/00960/FUL "Chris Brown" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address.
A summary of your comments is provided below.
Comments were submitted at 06/01/2010 14:01:31 from chris.brown@hinckley-bosworth.gov.uk
Application Summary

Application Number: 09/00960/FUL
Address:
Pats Cottage
Norton Lane
Little Orton
Orton On The Hill
Atherstone
Leicestershire
CV9 3NR
Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING INCUDING CREATION OF NEW ACCESS.
Case Officer:
David Kiernan
Customer Details

Name:
Chris Brown
Address:
empty
Comments:
Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet. (See Environment Agency guidance on the permeable surfacing of front gardens)
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.