Lisa Clarke

From: planning@hinckley-bosworth.gov.uk
Posted At: 02 March 2009 12:37
Conversation: ConsulteeAccess for Planning - Application Comments (09/00133/FUL)
Posted To: Inbox

Subject: ConsulteeAccess for Planning - Application Comments (09/00133/FUL)

ConsulteeAccess for Planning - Application Comments (09/00133/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 02/03/2009 12:36:30 from IP 192.168.0.3.

Application Summary

Application Number:
09/00133/FUL

Address:
Knoll Farm
Forest Road
Markfield
Leicestershire
LE67 9UN

Proposal:
ERECTION OF CHALET FOR RESIDENTIAL DWELLING.

Case Officer:

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
It is unlikely that a surface water sewer exists in the locality. surface water runoff from roofs and clean surfaces should, therefore, discharge to a soakaway or to the pond - but not to the foul sewer.

Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground

strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet, ie. the pond (See Environment Agency guidance on the permeable surfacing of front gardens)

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.