HIGHWAYS AGENCY

Richard Wright
Hinckley & Bosworth Borough Council
Council Offices
Argents Meads
Hinckley
Leicestershire
LE10 1BZ

C3
5 Broadway
Broad Street
BIRMINGHAM B15 1BL

Direct Line: 0121 687 2502

Our ref: K517052
Your ref: C&PS/P/DC/RJW/09/00042/FUL

29 July 2009

Dear Richard,

**M1 – KIRBY GRANGE FARM, TAVERNER DRIVE, RATBY, LEICESTER**
**DISCHARGE OF CONDITION 3 - 09/00042/FUL – ERECTION OF REPLACEMENT BUILDING**

Further to my response of 30th June, I now have the report from a Network Inspector's site visit on the 27th July.

Upon inspection of the site, the following drainage layout is evident:

- There is an existing 250mm diameter pipe from the property discharging to the ditch;
- This discharges at approximately 750mm in height from above the ditch bottom.
- The ditch itself is well formed at 1 50m wide x 1 50m deep, and has free-flowing water.

With the attenuation proposed, I am now content that there will be no adverse impact on the motorway or its drainage. I am therefore content for the condition to be discharged.

Yours faithfully

Geoff Wise
Planning Manager