Robert Morgan
Administration & Technical Assistant
Development Services
Hinckley & Bosworth Borough Council
Council Offices
Argents Mead
Hinckley
Leicestershire
LE10 1BZ

Our ref: 052 Park House Farm

17 October 2012

Dear Rob,

DISCHARGE OF CONDITIONS FOR ERECTION OF TWO WIND TURBINES INCLUDING ASSOCIATED TRANSFORMER AND CONTROL COMPOUNDS AND FORMATION OF ASSOCIATED INFRASTRUCTURE
APPLICANT: PAUL HILYER
PLANNING APPLICATION NUMBER: 11/00329/FUL

With regard to condition 7 attached to the above planning permission, I am writing to outline the details of a scheme setting out a protocol for the investigation and alleviation of shadow flicker.

The information is submitted as part of the Application for approval of details reserved by condition, **Planning Portal reference 02233826**.

Condition 7:

Prior to First Export Date, a scheme setting out a protocol for the investigation and alleviation of shadow flicker by the turbines hereby permitted in the event of any complaint being received from residential dwellings within a distance of ten rotor diameters of the turbines, shall be submitted to and approved in writing by the Local Planning Authority. The approved mitigation measures shall be carried out in accordance in writing by the Local Planning Authority and be kept in place for the duration of the permission.

In the event of a complaint the client would undertake a detailed shadow flicker assessment which would highlight the hours of the year that shadow flicker may occur. The turbine is remotely controlled by Scada software and as such the software can be programmed so that the turbine is automatically stopped during the anticipated periods of shadow flicker.

I hope that this meets the Council's requirements to discharge this condition. We look forward to the formal discharge letter at your earliest convenience.

Yours Sincerely

Paula Jamieson
Planner
ICE Renewables