PLANNING APPLICATION COMMENT SHEET

SHU	**08/01107/FUL**	County Landscape Products Brookfield Road
24.11.2008	**CTF**	Burbage
DEL		ERECTION OF BUILDERS MERCHANTS BUILDING WITH TRADE COUNTER AND ALTERATION OF EXISTING EXTERNAL STORAGE
		Applicant : Keyline Builders Merchants Ltd
		Ward : Burbage Sketchley & Stretton

ENVIRONMENTAL SERVICES COMMENTS.

If there are to be substantial areas of re-paving associated with the building development, an appropriately robust permeable paving system should be used in access ways, turning and parking areas. Otherwise, surface water runoff from access roads, parking, turning, loading and fuelling areas shall be routed through suitably sited oil separators before discharge to receiving waters.

C Brown
Land drainage Engineer
Date: 22/12/08

SIGNATURE: DATE