

Leicestershire County Council

22 May 2026

SHD

info@shdlighting.co.uk 07834 490 192 www.shdlighting.co.uk

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.

SHD2688-SHD-HLG-STOK-SH-EO-Lighting Schedule-R1



NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Unit Location	Unit Description	Service Connection Type	Primary Isolator	Secondary Isolator	Private Cable Network Termination Type
LC53	441952.3239	295767.5251	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC54	442033.7363	295749.4848	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC55	442016.3092	295778.3144	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC56	442010.0014	295803.8228	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC57	442379.8144	295911.3715	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 3.73km 34w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC58	442363.9376	295931.3177	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC59	442346.2667	295953.6458	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC60	442317.5322	295975.0244	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC61	442321.4999	295995.0587	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC62	442298.2618	295988.6428	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC63	442336.7278	295939.5141	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC64	442304.4727	295925.8323	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC65	442278.9523	295905.2033	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A
LC66	442288.7351	295891.8760	Refer to 'SHD2688-SHD-HLG-STOK-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base and glass flake epoxy root treatment as supplied by Fabrikat, CU Phosco, Mallatite or similar approved lighting column to Leicestershire County Council street lighting specification with post top mounted at 0° tilt, ASD Lighting Highway Diamond Micro (HWD2 3K12 700 M1 CLO Gen 7) 2.93km 26w warm white (3000k) LED luminaire and Telensa Telecell CMS node incorporating GPS, to integrate into Leicestershire central management system.	Proposed IDNO supply connection	IDNO approved double pole isolator	N/A	N/A