
From: public.access@hinckley-bosworth.gov.uk
Sent: 11 March 2024 16:05
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00149/P3CQ

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 11/03/2024 4:04 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/00149/P3CQ
Address:	Pond Barn Cold Comfort Farm Rogues Lane Hinckley Leicestershire
Proposal:	Change of use of agricultural steel framed barn into a single dwellinghouse (C3) (Revised Scheme of planning application 23/01012/P3CQ)
Case Officer:	Sullivan Archer

[Click for further information](#)

Comments Details

Advice to Applicant:

According to the Environment Agency (EA) website, the application site is located within Flood Zone 1, designated as low probability of flooding from rivers and sea, and the principle of residential development in low flood risk areas is acceptable. The EA Surface Water mapping indicates that there is a medium risk of flooding from surface water to the northern extent of the site.

Comments:

The surface water drainage system for the proposed development should incorporate sustainable drainage principles (SuDS) to mitigate the risk of flooding on the site, and ensure that surface water runoff does not increase flood risk elsewhere. The proposals should also include measures to address issues of water quality in accordance with current SuDS guidance.

The proposed outfall for the discharge of surface water runoff from the development should be in accordance with the hierarchical approach outlined in Building Regulations Part H.

The use of infiltration drainage is preferred, subject to the site being free from a contaminated ground legacy. The suitability of the ground strata for soakaway drainage should be ascertained by means of the test described in BRE Digest 365, and the results approved by the Building Control Surveyor before development is commenced

If the ground strata are insufficiently permeable to avoid discharging some surface water off-site, flow attenuation methods should be employed, either alone or in combination with infiltration systems and/or rainwater harvesting systems.

Kind regards