Norma Gudger

From: planning@hinckley-bosworth.gov.uk
Posted At: 20 October 2009 11:24
Conversation: ConsulteeAccess for Planning - Application Comments (09/00732/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00732/FUL)

ConsulteeAccess for Planning - Application Comments (09/00732/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 20/10/2009 11:24:00 from IP 192.168.0.3.

Application Summary

Application Number:
09/00732/FUL

Address:
123 Westfield Road
Hinckley
Leicestershire
LE10 0LT

Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING

Case Officer:
David Kiernan

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet.