

Tiffany MacDonald

Subject: FW: 23/00378/FUL- Outside Settlement Boundary - BURBAGE 202672
Attachments: 23.00378.FUL Env Health Comments.pdf

Sent: 03 May 2023 13:06

To: David Spring <David.Spring@hinckley-bosworth.gov.uk>

Subject: FW: 23/00378/FUL- Outside Settlement Boundary - BURBAGE 202672

Good afternoon David


Re your email below and attachment. The noise from the inverter is so low as negligible.
The inverter noise level is Noise emission (typical): ≤ 65 dB(A)

The inverter locations will be on the ground mount array.

Please come back to me if you require any further assistance.

With thanks

Jules Edwards
Office Manager



Before printing this mail or any of its attachments, please be sure it is absolutely necessary. Protection of the environment is everyone's responsibility. We have the right to enjoy it but also the obligation to preserve it.

The contents of this e-mail are confidential to the intended recipient at the e-mail address to which it has been addressed. It may not be disclosed to or used by anyone other than this addressee nor may it be copied in any way. If received in error please notify us immediately and delete the e-mail. Alt-Energi Services Limited (Reg No 11056450) and Alt-Solar Ltd (Reg No 11867547), operate under the Alt-Group Brand. Neither Alt-Group, it's divisions nor the sender accepts any liability or responsibility for viruses and it is your responsibility to scan any attachments.

