

---

**From:** public.access@hinckley-bosworth.gov.uk  
**Sent:** 23 September 2025 12:04  
**To:** Planning Application Comments  
**Subject:** Consultee Comments for Planning Application 25/00813/FUL  
**Categories:** Sonia

## Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 23/09/2025 12:04 PM from Mr Peter Reid ([peter.reid@hinckley-bosworth.gov.uk](mailto:peter.reid@hinckley-bosworth.gov.uk)) on behalf of HBBC Drainage.

### Application Summary

Reference:	25/00813/FUL
Address:	Land Adjacent To 6 Meadow Lane Stanton Under Bardon Coalville Leicestershire LE67 9TL
Proposal:	Erection of 27 dwellings with associated access, parking, landscaping and drainage
Case Officer:	Sullivan Archer

[Click for further information](#)

### Comments Details

No objection subject to the following conditions:

Development shall not begin until a scheme to provide a sustainable surface water drainage system in accordance with the Flood Risk Technical Note and Drainage Strategy dated June 2025 has been submitted to and approved by the Local Planning Authority, and the scheme shall subsequently be implemented in accordance with the approved details before the development is completed.

Comments:

Prior to commencement of development details in relation to the management of surface water on site during construction of the development shall be submitted to, and approved in writing by, the Local Planning Authority. Details should demonstrate how surface water will be managed on site to prevent an increase in flood risk during the various construction stages of development from initial site works through to completion. This shall include temporary attenuation, additional treatment, controls, maintenance and protection. Details regarding the protection of any proposed infiltration areas should also be provided.

Prior to commencement of development details in relation to the long term maintenance of the sustainable surface water drainage system on the development shall be submitted to and approved in writing by the Local Planning Authority. Details of the SuDS Maintenance Plan should include responsibilities

and schedules for routine maintenance, remedial actions and monitoring of the separate elements of the system and should also include procedures that must be implemented in the event of pollution incidents within the development site.

---

Kind regards