Jane Steel

From: planning@hinckley-bosworth.gov.uk
Posted At: 26 August 2010 12:04
Conversation: ConsulteeAccess for Planning - Application Comments (10/00303/ADV)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (10/00303/ADV)

ConsulteeAccess for Planning - Application Comments (10/00303/ADV)

"L.C.C. Highways" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00303/ADV "L.C.C. Highways" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address. A summary of your comments is provided below.
Comments were submitted at 26/08/2010 12:03:35 from Application Summary
---
Application Number: 10/00303/ADV
Address:
17 Castle Street
Hinckley
Leicestershire
LE10 1DA
Proposal:
ERECTION OF SIGNAGE
Case Officer:
Louise Forman
Customer Details

Name:
L.C.C. Highways
Address:
empty
Comments:
Could you please consider the Highway Authority response through the 'Standing advice' procedure with the following comments?:
The maximum luminance of the light source shall not exceed 1000 cd/m2.
The projecting sign shall have a minimum height of not less than 2.4 metres above the level of the footway.
Note- The Applicant will be required to obtain consent from the Highway Authority for any elements of the frontage which overhang the public highway (telephone 0116 3052202).
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.